

IPMC'

INTERNATIONAL **PROPERTY**MAINTENANCE CODE®





Receive **FREE** updates, excerpts of code references, technical articles, and more when you register your code book. Go to

www.iccsafe.org/CodesPlus today!



First Printing: January 2009 Second Printing: May 2009 Third Printing: March 2010

ISBN: 978-1-58001-740-4 (soft-cover edition)

COPYRIGHT © 2009 by INTERNATIONAL CODE COUNCIL, INC.

ALL RIGHTS RESERVED. This 2009 International Property Maintenance Code® is a copyrighted work owned by the International Code Council, Inc. Without advance written permission from the copyright owner, no part of this book may be reproduced, distributed or transmitted in any form or by any means, including, without limitation, electronic, optical or mechanical means (by way of example, and not limitation, photocopying or recording by or in an information storage retrieval system). For information on permission to copy material exceeding fair use, please contact: Publications, 4051 West Flossmoor Road, Country Club Hills, IL 60478. Phone 1-888-ICC-SAFE (422-7233).

Trademarks: "International Code Council," the "International Code Council" logo and the "International Property Maintenance Code" are trademarks of the International Code Council, Inc.

PREFACE MARKET AND THE REPORT AND THE PROPERTY AND THE PR

Introduction

Internationally, code officials recognize the need for a modern, up-to-date property maintenance code governing the maintenance of existing buildings. The *International Property Maintenance Code®*, in this 2009 edition, is designed to meet this need through model code regulations that contain clear and specific property maintenance requirements with required property improvement provisions.

This 2009 edition is fully compatible with all International Codes® (I-Codes®) published by the International Code Council (ICC)®, including the International Building Code®, International Energy Conservation Code®, International Existing Building Code®, International Fire Code®, International Fuel Gas Code®, International Mechanical Code®, ICC Performance Code®, International Plumbing Code®, International Private Sewage Disposal Code®, International Residential Code®, International Wildland-Urban Interface Code® and International Zoning Code®.

The International Property Maintenance Code provisions provide many benefits, among which is the model code development process that offers an international forum for code officials and other interested parties to discuss performance and prescriptive code requirements. This forum provides an excellent arena to debate proposed revisions. This model code also encourages international consistency in the application of provisions.

Development

The first edition of the *International Property Maintenance Code* (1998) was the culmination of an effort initiated in 1996 by a code development committee appointed by ICC and consisting of representatives of the three statutory members of the International Code Council at that time, including: Building Officials and Code Administrators International, Inc. (BOCA), International Conference of Building Officials (ICBO) and Southern Building Code Congress International (SBCCI). The committee drafted a comprehensive set of regulations for existing buildings that was consistent with the existing model property maintenance codes at the time. This 2009 edition presents the code as originally issued, with changes reflected through the previous 2006 editions and further changes developed through the ICC Code Development Process through 2008. A new edition of the code is promulgated every three years.

This code is founded on principles intended to establish provisions consistent with the scope of a property maintenance code that adequately protects public health, safety and welfare; provisions that do not unnecessarily increase construction costs; provisions that do not restrict the use of new materials, products or methods of construction; and provisions that do not give preferential treatment to particular types or classes of materials, products or methods of construction.

Adoption

The International Property Maintenance Code is available for adoption and use by jurisdictions internationally. Its use within a governmental jurisdiction is intended to be accomplished through adoption by reference in accordance with proceedings established in the jurisdiction's laws. At the time of adoption, jurisdictions should insert the appropriate information in provisions requiring specific local information, such as the name of the adopting jurisdiction. These locations are shown in bracketed words in small capital letters in the code and in the sample ordinance. The sample adoption ordinance on page vii addresses several key elements of a code adoption ordinance, including the information required for insertion into the code text.

Maintenance

The International Property Maintenance Code is kept up to date through the review of proposed changes submitted by code enforcing officials, industry representatives, design professionals and other interested parties. Proposed changes are carefully considered through an open code development process in which all interested and affected parties may participate.

The contents of this work are subject to change both through the Code Development Cycles and the governmental body that enacts the code into law. For more information regarding the code development process, contact the Codes and Standards Development Department of the International Code Council.

While the development procedure of the *International Property Maintenance Code* ensures the highest degree of care, ICC, its membership and those participating in the development of this code do not accept any liability resulting from compliance or non-compliance with the provisions because ICC does not have the power or authority to police or enforce compliance with the contents of this code. Only the governmental body that enacts the code into law has such authority.

Letter Designations in Front of Section Numbers

In each code development cycle, proposed changes to this code are considered at the Code Development Hearings by the ICC Property Maintenance/Zoning Code Development Committee, whose action constitutes a recommendation to the voting membership for final action on the proposed changes. Proposed changes to a code section having a number beginning with a letter in brackets are considered by a different code development committee. For example, proposed changes to code sections that have the letter [F] in front of them (e.g., |F| 704.1) are considered by the International Fire Code Development Committee at the Code Development Hearings.

The content of sections in this code that begin with a letter designation are maintained by another code development committee in accordance with the following:

- [F] = International Fire Code Development Committee;
- (P) = International Plumbing Code Development Committee; and
- [B] = International Building Code Development Committee.

Marginal Markings

Solid vertical lines in the margins within the body of the code indicating a technical change from the requirements of the previous edition. Deletion indicators in the form of an arrow (\Rightarrow) are provided in the margin where an entire section, paragraph, exception or table has been deleted or an item in a list of items or a table has been deleted.

Italicized Terms

Selected terms set forth in Chapter 2, Definitions, are italicized where they appear in code text. Such terms are not italicized where the definition set forth in Chapter 2 does not impart the intended meaning in the use of the term. The terms selected have definitions which the user should read carefully to facilitate better understanding of the code.

A THE SET OF COME SET OF THE PROPERTY OF THE SET OF THE

Market 1

Effective Use of the International Property Maintenance Code

The International Property Maintenance Code (IPMC) is a model code that regulates the minimum maintenance requirements for existing buildings.

The IPMC is a maintenance document intended to establish minimum maintenance standards for basic equipment, light, ventilation, heating, sanitation and fire safety. Responsibility is fixed among owners, operators and occupants for code compliance. The IPMC provides for the regulation and safe use of existing structures in the interest of the social and economic welfare of the community.

Arrangement and Format of the 2009 IPMC

Before applying the requirements of the IPMC it is beneficial to understand its arrangement and format. The IPMC, like other codes published by ICC, is arranged and organized to follow sequential steps that generally occur during an inspection. The IPMC is divided into eight different parts:

Chapters	Subjects			
	Administration			
2	Definitions			
3	General Requirements			
4	Light, Ventilation and Occupancy Limitations			
1 1 - 5 ···	Plumbing Facilities and Fixture Requirements			
6	Mechanical and Electrical Requirements			
7	Fire Safety Requirements			
8	Referenced Standards			

The following is a chapter-by-chapter synopsis of the scope and intent of the provisions of the International Property Maintenance Code:

Chapter 1 Administration. This chapter contains provisions for the application, enforcement and administration of subsequent requirements of the code. In addition to establishing the scope of the code, Chapter 1 identifies which buildings and structures come under its purview. Chapter 1 is largely concerned with maintaining "due process of law" in enforcing the property maintenance criteria contained in the body of the code. Only through careful observation of the administrative provisions can the building official reasonably expect to demonstrate that "equal protection under the law" has been provided.

Chapter 2 Definitions. All terms that are defined in the code are listed alphabetically in Chapter 2. While a defined term may be used in one chapter or another, the meaning provided in Chapter 2 is applicable throughout the code.

Where understanding of a term's definition is especially key to or necessary for understanding of a particular code provision, the term is show in italics wherever it appears in the code. This is true only for those terms that have a meaning that is unique to the code. In other words, the generally understood meaning of a term or phrase might not be sufficient or consistent with the meaning prescribed by the code; therefore, it is essential that the code-defined meaning be known.

Guidance regarding tense, gender and plurality of defined terms as well as guidance regarding terms not defined in this code is provided.

Chapter 3 General Requirements. Chapter 3, "General Requirements," is broad in scope. It includes a variety of requirements for the exterior property areas as well as the interior and exterior elements of the structure. This chapter provides requirements that are intended to maintain a minimum level of safety and sanitation for both the general public and the occupants of a structure, and to maintain a building's structural and weather-resistance performance. Chapter 3 provides specific criteria for regulating the installation and maintenance of specific building components; maintenance requirements for vacant structures and land; requirements regulating the safety, sanitation and appearance of the interior and exterior of structures and all exterior property areas; accessory structures; vehicle storage regulations and establishes who is responsible for complying with the chapter's provisions. This chapter also contains the requirements for swimming pools, spas and hot tubs and the requirements for protective barriers and gates in these

barriers. Chapter 3 establishes the responsible parties for exterminating insects and rodents, and maintaining sanitary conditions in all types of occupancies.

Chapter 4 Light, Ventilation and Occupancy Limitations. The purpose of Chapter 4 is to set forth these requirements in the code and to establish the minimum environment for occupiable and habitable buildings, by establishing the minimum criteria for light and ventilation and identifies occupancy limitations including minimum room width and area, minimum ceiling height and restrictions to prevent overcrowding. This chapter also provides for alternative arrangements of windows and other devices to comply with the requirements for light and ventilation and prohibits certain room arrangements and occupancy uses.

Chapter 5 Plumbing Facilities and Fixture Requirements. Chapter 5 establishes the minimum criteria for the installation, maintenance and location of plumbing systems and facilities, including the water supply system, water heating appliances, sewage disposal system and related plumbing fixtures.

Sanitary and clean conditions in occupied buildings are dependent upon certain basic plumbing principles, including providing potable water to a building, providing the basic fixtures to effectively utilize that water and properly removing waste from the building. Chapter 5 establishes the minimum criteria to verify that these principles are maintained throughout the life of a building.

Chapter 6 Mechanical and Electrical Requirements. The purpose of Chapter 6 is to establish minimum performance requirements for heating, electrical and mechanical facilities and to establish minimum standards for the safety of these facilities.

This chapter establishes minimum criteria for the installation and maintenance of the following: heating and air-conditioning equipment, appliances and their supporting systems; water-heating equipment, appliances and systems; cooking equipment and appliances; ventilation and exhaust equipment; gas and liquid fuel distribution piping and components; fireplaces and solid fuel-burning appliances; chimneys and vents; electrical services; lighting fixtures; electrical receptacle outlets; electrical distribution system equipment, devices and wiring; and elevators, escalators and dumbwaiters.

Chapter 7 Fire Safety Requirements. The purpose of Chapter 7 is to address those fire hazards that arise as the result of a building's occupancy. It also provides minimum requirements for fire safety issues that are most likely to arise in older buildings.

This chapter contains requirements for means of egress in existing buildings, including path of travel, required egress width, means of egress doors and emergency escape openings.

Chapter 7 establishes the minimum requirements for fire safety facilities and fire protection systems, as these are essential fire safety systems.

Chapter 8 Referenced Standards. The code contains numerous references to standards that are used to regulate materials and methods of construction. Chapter 8 contains a comprehensive list of all standards that are referenced in the code. The standards are part of the code to the extent of the reference to the standard. Compliance with the referenced standard is necessary for compliance with this code. By providing specifically adopted standards, the construction and installation requirements necessary for compliance with the code can be readily determined. The basis for code compliance is, therefore, established and available on an equal basis to the code official, contractor, designer and owner.

Chapter 8 is organized in a manner that makes it easy to locate specific standards. It lists all of the referenced standards, alphabetically, by acronym of the promulgating agency of the standard. Each agency's standards are then listed in either alphabetical or numeric order based upon the standard identification. The list also contains the title of the standard; the edition (date) of the standard referenced; any addenda included as part of the ICC adoption; and the section or sections of this code that reference the standard.

Provided through a servicion or and political and recovery and advantage of a service and are produced for

The section is the section of the se

the to access orders assess a treefer to remaining ordered. Signific climited drift from \$100 to and \$100 to \$

The college of the co

ORDINANCE

The International Codes are designed and promulgated to be adopted by reference by ordinance. Jurisdictions wishing to adopt the 2009 International Property Maintenance Code as an enforceable regulation governing existing structures and premises should ensure that certain factual information is included in the adopting ordinance at the time adoption is being considered by the appropriate governmental body. The following sample adoption ordinance addresses several key elements of a code adoption ordinance, including the information required for insertion into the code text.

SAMPLE ORDINANCE FOR ADOPTION OF THE INTERNATIONAL PROPERTY MAINTENANCE CODE ORDINANCE NO.

An ordinance of the [JURISDICTION] adopting the 2009 edition of the International Property Maintenance Code, regulating and governing the conditions and maintenance of all property, buildings and structures; by providing the standards for supplied utilities and facilities and other physical things and conditions essential to ensure that structures are safe, sanitary and fit for occupation and nse; and the condemnation of buildings and structures unfit for human occupancy and use, and the demolition of such existing structures in the [JURISDICTION]; providing for the issuance of permits and collection of fees therefor; repealing Ordinance No. ______ of the [JURISDICTION] and all other ordinances and parts of the ordinances in conflict therewith.

The [GOVERNING BODY] of the [JURISDICTION] does ordain as follows:

Section 1. That a certain document, three (3) copies of which are on file in the office of the [TITLE OF JURISDICTION'S KEEPER OF RECORDS] of [NAME OF JURISDICTION], being marked and designated as the International Property Maintenance Code, 2009 edition, as published by the International Code Council, be and is hereby adopted as the Property Maintenance Code of the [JURISDICTION], in the State of [STATE NAME] for regulating and governing the conditions and maintenance of all property, buildings and structures; by providing the standards for supplied utilities and facilities and other physical things and conditions essential to ensure that structures are safe, sanitary and fit for occupation and use; and the condemnation of buildings and structures unfit for human occupancy and use, and the demolition of such existing structures as herein provided; providing for the issuance of permits and collection of fees therefor; and each and all of the regulations, provisions, penalties, conditions and terms of said Property Maintenance Code on file in the office of the [JURISDICTION] are hereby referred to, adopted, and made a part hereof, as if fully set out in this ordinance, with the additions, insertions, deletions and changes, if any, prescribed in Section 2 of this ordinance.

Section 2. The following sections are hereby revised:

Section 101.1. Insert: [NAME OF JURISDICTION]

Section 103.5. Insert: [APPROPRIATE SCHEDULE]

Section 112.4. Insert: [DOLLAR AMOUNT IN TWO LOCATIONS]

Section 302.4. Insert: [HEIGHT IN INCHES]

Section 304.14. Insert: [DATES IN TWO LOCATIONS]
Section 602.3. Insert: [DATES IN TWO LOCATIONS]

Section 602.4. Insert: [DATES IN TWO LOCATIONS]

Section 3. That Ordinance No. _____ of [JURISDICTION] entitled [FILL IN HERE THE COMPLETE TITLE OF THE ORDINANCE OR ORDINANCES IN EFFECT AT THE PRESENT TIME SO THAT THEY WILL BE REPEALED BY DEFINITE MENTION] and all other ordinances or parts of ordinances in conflict herewith are hereby repealed.

Section 4. That if any section, subsection, sentence, clause or phrase of this ordinance is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this ordinance. The [GOVERNING BODY] hereby declares that it would have passed this ordinance, and each section, subsection, clause or phrase thereof, irrespective of the faet that any one or more sections, subsections, sentences, clauses and phrases be declared unconstitutional.

Section 5. That nothing in this ordinance or in the Property Maintenance Code hereby adopted shall be construed to affect any suit or proceeding impending in any court, or any rights acquired, or liability incurred, or any cause or causes of action acquired or existing, under any act or ordinance hereby repealed as cited in Section 3 of this ordinance; nor shall any just or legal right or remedy of any character be lost, impaired or affected by this ordinance.

Section 6. That the [JURISDICTION'S KEEPER OF RECORDS] is hereby ordered and directed to cause this ordinance to be published. (An additional provision may be required to direct the number of times the ordinance is to be published and to specify that it is to be in a newspaper in general circulation. Posting may also be required.)

Section 7. That this ordinance and the rules, regulations, provisions, requirements, orders and matters established and adopted hereby shall take effect and be in full force and effect [TIME PERIOD] from and after the date of its final passage and adoption.

THE WITHINGTON AND PROPERTY MAINTENANCE COOR

AND THE PROPERTY OF THE PARTY O

TABLE OF CONTENTS

CHAPTER 1 ADMINISTRATION		404 Occupancy Limitations			
PART 1—SCOPE AND APPLICATION			PTER 5	PLUMBING FACILITIES AND FIXTURE REQUIREMENTS 19	
101 General		Section			
102	Applicability 1	501	General		
		502		d Facilities19	
PART	2—ADMINISTRATION AND ENFORCEMENT		Toilet Rooms		
103	Department of Property Maintenance			g Systems and Fixtures	
105	Inspection	504 505		ystem	
104	Duties and Powers of the Code Official2			Drainage System	
105	Approval2		-	Orainage	
106	Violations	507	Storm L	ramage	
107	Notices and Orders 3	СНА	PTER 6	MECHANICAL AND ELECTRICAL	
108	Unsafe Structures and Equipment4	СПА	LIERU	REQUIREMENTS	
109	Emergency Measures5	Section	םכ		
110	Demolition	601	General		
111	Means of Appeal 6	602		Facilities	
112	Stop Work Order 6	603	_	ical Equipment	
CHAPTER 2 DEFINITIONS		604	Electric	al Facilities	
		605	Electric	al Equipment22	
201	General9	606	Elevator	rs, Escalators and Dumbwaiters 22	
202	General Definitions	607	Duct Sy	stems	
CHAPTER 3 GENERAL REQUIREMENTS11			PTER 7	FIRE SAFETY	
Section	n			REQUIREMENTS	
301	General11	Section	חכ		
302	Exterior Property Areas	701			
303	Swimming Pools, Spas and Hot Tubs	702	Means o	of Egress	
304	Exterior Structure	703	Fire-res	istance Ratings	
305	Interior Structure	704	Fire Pro	tection Systems	
306	Component Serviceability				
307	Handrails and Guardrails	CHA	PTER 8	REFERENCED STANDARDS 27	
308	Rubbish and Garbage				
309	Pest Elimination		APPENDIX A BOARDING STANDARD29		
СНАЕ	PTER 4 LIGHT, VENTILATION AND	Section	n		
OCCUPANCY LIMITATIONS17			A 101 General		
Section			A 102 Materials		
401	General17		A 103 Installation		
402	Light				
403	Ventilation		EX	31	

PART HOSPITERING

SCOPE AND ADMINISTRATION

PART 1—SCOPE AND APPLICATION

SECTION 101 GENERAL

101.1 Title. These regulations shall be known as the *International Property Maintenance Code* of [NAME OF JURISDICTION], hereinafter referred to as "this code."

101.2 Scope. The provisions of this code shall apply to all existing residential and nonresidential structures and all existing premises and constitute minimum requirements and standards for premises, structures, equipment and facilities for light, ventilation, space, heating, sanitation, protection from the elements, life safety, safety from fire and other hazards, and for safe and sanitary maintenance; the responsibility of owners, operators and occupants; the occupancy of existing structures and premises, and for administration, enforcement and penalties.

101.3 Intent. This code shall be construed to secure its expressed intent, which is to ensure public health, safety and welfare insofar as they are affected by the continued occupancy and maintenance of structures and premises. Existing structures and premises that do not comply with these provisions shall be altered or repaired to provide a minimum level of health and safety as required herein.

101.4 Severability. If a section, subsection, sentence, clause or phrase of this code is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this code.

SECTION 102 APPLICABILITY

102.1 General. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall govern. Where differences occur between provisions of this code and the referenced standards, the provisions of this code shall apply. Where, in a specific case, different sections of this code specify different requirements, the most restrictive shall govern.

102.2 Maintenance. Equipment, systems, devices and safeguards required by this code or a previous regulation or code under which the structure or premises was constructed, altered or repaired shall be maintained in good working order. No owner, operator or occupant shall cause any service, facility, equipment or utility which is required under this section to be removed from or shut off from or discontinued for any occupied dwelling, except for such temporary interruption as necessary while repairs or alterations are in progress. The requirements of this code are not intended to provide the basis for removal or abrogation of fire protection and safety systems and devices in existing structures. Except as otherwise specified herein, the owner or the owner's designated agent shall be

responsible for the maintenance of buildings, structures and premises.

102.3 Application of other codes. Repairs, additions or alterations to a structure, or changes of occupancy, shall be done in accordance with the procedures and provisions of the International Building Code, International Fuel Gas Code, International Mechanical Code and NFPA 70. Nothing in this code shall be construed to cancel, modify or set aside any provision of the International Zoning Code.

192.4 Existing remedies. The provisions in this code shall not be construed to abolish or impair existing remedies of the jurisdiction or its officers or agencies relating to the removal or demolition of any structure which is dangerous, unsafe and insanitary.

102.5 Workmanship. Repairs, maintenance work, alterations or installations which are caused directly or indirectly by the enforcement of this code shall be executed and installed in a workmanlike manner and installed in accordance with the manufacturer's installation instructions.

102.6 Historic buildings. The provisions of this code shall not be mandatory for existing buildings or structures designated as historic buildings when such buildings or structures are judged by the *code official* to be safe and in the public interest of health, safety and welfare.

102.7 Referenced codes and standards. The codes and standards referenced in this code shall be those that are listed in Chapter 8 and considered part of the requirements of this code to the prescribed extent of each such reference. Where differences occur between provisions of this code and the referenced standards, the provisions of this code shall apply.

Exception: Where enforcement of a code provision would violate the conditions of the listing of the equipment or appliance, the conditions of the listing shall apply.

102.8 Requirements not covered by code. Requirements necessary for the strength, stability or proper operation of an existing fixture, structure or equipment, or for the public safety, health and general welfare, not specifically covered by this code, shall be determined by the code official.

102.9 Application of references. References to chapter or section numbers, or to provisions not specifically identified by number, shall be construed to refer to such chapter, section or provision of this code.

102.10 Other laws. The provisions of this code shall not be deemed to nullify any provisions of local, state or federal law.

■ PART 2—ADMINISTRATION AND ENFORCEMENT

SECTION 103 DEPARTMENT OF PROPERTY MAINTENANCE INSPECTION

- **103.1** General. The department of property maintenance inspection is hereby created and the executive official in charge thereof shall be known as the *code official*.
- **103.2 Appointment.** The *code official* shall be appointed by the chief appointing authority of the jurisdiction.
- 103.3 Deputies. In accordance with the prescribed procedures of this jurisdiction and with the concurrence of the appointing authority, the *code official* shall have the authority to appoint a deputy(s). Such employees shall have powers as delegated by the *code official*.
- 103.4 Liability. The code official, member of the board of appeals or employee charged with the enforcement of this code, while acting for the jurisdiction, in good faith and without malice in the discharge of the duties required by this code or other pertinent law or ordinance, shall not thereby be rendered liable personally, and is hereby relieved from all personal liability for any damage accruing to persons or property as a result of an act or by reason of an act or omission in the discharge of official duties. Any suit instituted against any officer or employee because of an act performed by that officer or employee in the lawful discharge of duties and under the provisions of this code shall he defended by the legal representative of the jurisdiction until the final termination of the proceedings. The code official or any subordinate shall not be liable for costs in an action, suit or proceeding that is instituted in pursuance of the provisions of this code.
- 103.5 Fees. The fees for activities and services performed by the department in carrying out its responsibilities under this code shall be as indicated in the following schedule.

[JURISDICTION TO INSERT APPROPRIATE SCHEDULE.]

SECTION 104 DUTIES AND POWERS OF THE CODE OFFICIAL

- 104.1 General. The code official is hereby authorized and directed to enforce the provisions of this code. The code official shall have the authority to render interpretations of this code and to adopt policies and procedures in order to clarify the application of its provisions. Such interpretations, policies and procedures shall he in compliance with the intent and purpose of this code. Such policies and procedures shall not have the effect of waiving requirements specifically provided for in this code.
- 104.2 Inspections. The code official shall make all of the required inspections, or shall accept reports of inspection by approved agencies or individuals. All reports of such inspections shall be in writing and be certified by a responsible officer of such approved agency or by the responsible individual. The code official is authorized to engage such expert opinion as

deemed necessary to report upon unusual technical issues that arise, subject to the approval of the appointing authority.

- 104.3 Right of entry. Where it is necessary to make an inspection to enforce the provisions of this code, or whenever the code official has reasonable cause to believe that there exists in a structure or upon a premises a condition in violation of this code, the code official is authorized to enter the structure or premises at reasonable times to inspect or perform the duties imposed by this code, provided that if such structure or premises is occupied the code official shall present credentials to the occupant and request entry. If such structure or premises is unoccupied, the code official shall first make a reasonable effort to locate the owner or other person having charge or control of the structure or premises and request entry. If entry is refused, the code official shall have recourse to the remedies provided by law to secure entry.
- **104.4 Identification.** The *code official* shall carry proper identification when inspecting *structures* or *premises* in the performance of duties under this code.
- 104.5 Notices and orders. The code official shall issue all necessary notices or orders to ensure compliance with this code.
- 104.6 Department records. The code official shall keep official records of all business and activities of the department specified in the provisions of this code. Such records shall be retained in the official records for the period required for retention of public records.

SECTION 105 APPROVAL

- 105.1 Modifications. Whenever there are practical difficulties involved in carrying out the provisions of this code, the *code official* shall have the authority to grant modifications for individual cases upon application of the *owner* or *owner*'s representative, provided the *code official* shall first find that special individual reason makes the strict letter of this code impractical and the modification is in compliance with the intent and purpose of this code and that such modification does not lessen health, life and fire safety requirements. The details of action granting modifications shall be recorded and entered in the department files.
- 105.2 Alternative materials, methods and equipment. The provisions of this code are not intended to prevent the installation of any material or to prohibit any method of construction not specifically prescribed by this code, provided that any such alternative has been approved. An alternative material or method of construction shall be approved where the code official finds that the proposed design is satisfactory and complies with the intent of the provisions of this code, and that the material, method or work offered is, for the purpose intended, at least the equivalent of that prescribed in this code in quality, strength, effectiveness, fire resistance, durability and safety.
- 105.3 Required testing. Whenever there is insufficient evidence of compliance with the provisions of this code, or evidence that a material or method does not conform to the requirements of this code, or in order to substantiate claims for

alternative materials or methods, the code official shall have the authority to require tests to be made as evidence of compliance at no expense to the jurisdiction.

105.3.1 Test methods. Test methods shall be as specified in this code or by other recognized test standards. In the absence of recognized and accepted test methods, the code official shall be permitted to approve appropriate testing procedures performed by an approved agency.

105.3.2 Test reports. Reports of tests shall be retained by the code official for the period required for retention of public records.

105.4 Used material and equipment. The use of used materials which meet the requirements of this code for new materials is permitted. Materials, equipment and devices shall not be reused unless such elements are in good repair or have been reconditioned and tested when necessary, placed in good and proper working condition and approved by the code official.

105.5 Approved materials and equipment. Materials, equipment and devices approved by the code official shall be constructed and installed in accordance with such approval.

105.6 Research reports. Supporting data, where necessary to assist in the approval of materials or assemblies not specifically provided for in this code, shall consist of valid research reports from approved sources.

SECTION 106 VIOLATIONS

106.1 Unlawful acts. It shall be unlawful for a person, firm or corporation to be in conflict with or in violation of any of the provisions of this code.

106.2 Notice of violation. The code official shall serve a notice of violation or order in accordance with Section 107.

106.3 Prosecution of violation. Any person failing to comply with a notice of violation or order served in accordance with Section 107 shall be deemed guilty of a misdemeanor or civil infraction as determined by the local municipality, and the violation shall be deemed a strict liability offense. If the notice of violation is not complied with, the code official shall institute the appropriate proceeding at law or in equity to restrain, correct or abate such violation, or to require the removal or termination of the unlawful occupancy of the structure in violation of the provisions of this code or of the order or direction made pursuant thereto. Any action taken hy the authority having jurisdiction on such premises shall be charged against the real estate upon which the structure is located and shall be a lien upon such real estate.

106.4 Violation penalties. Any person who shall violate a provision of this code, or fail to comply therewith, or with any of the requirements thereof, shall be prosecuted within the limits provided by state or local laws. Each day that a violation continues after due notice has been served shall be deemed a separate offense.

106.5 Abatement of violation. The imposition of the penalties herein prescribed shall not preclude the legal officer of the jurisdiction from instituting appropriate action to restrain, correct or abate a violation, or to prevent illegal occupancy of a building, structure or premises, or to stop an illegal act, conduct, business or utilization of the building, structure or pre-

SECTION 107 NOTICES AND ORDERS

107.1 Notice to person responsible. Whenever the code official determines that there has been a violation of this code or has grounds to believe that a violation has occurred, notice shall be given in the manner prescribed in Sections 107.2 and 107.3 to the person responsible for the violation as specified in this code. Notices for condemnation procedures shall also comply with Section 108.3.

107.2 Form. Such notice prescribed in Section 107.1 shall be in accordance with all of the following: 1. Be in writing.

- 2. Include a description of the real estate sufficient for identification.
- 3. Include a statement of the violation or violations and why the notice is being issued.
- 4. Include a correction order allowing a reasonable time to make the repairs and improvements required to bring the dwelling unit or structure into compliance with the provisions of this code.
- 5. Inform the property owner of the right to appeal.
- 6. Include a statement of the right to file a lien in accordance with Section 106.3.

107.3 Method of service. Such notice shall be deemed to be properly served if a copy thereof is:

- 1. Delivered personally;
- 2. Sent by certified or first-class mail addressed to the last known address: or
- 3. If the notice is returned showing that the letter was not delivered, a copy thereof shall be posted in a conspicuous place in or about the structure affected by such notice.

107.4 Unauthorized tampering. Signs, tags or seals posted or affixed by the code official shall not be mutilated, destroyed or tampered with, or removed without authorization from the code official.

107.5 Penalties. Penalties for noncompliance with orders and notices shall be as set forth in Section 106.4.

107.6 Transfer of ownership. It shall be unlawful for the owner of any dwelling unit or structure who has received a compliance order or upon whom a notice of violation has been served to sell, transfer, mortgage, lease or otherwise dispose of such dwelling unit or structure to another until the provisions of the compliance order or notice of violation have been complied with, or until such owner shall first furnish the grantee, transferee, mortgagee or lessee a true copy of any compliance order or notice of violation issued by the code official and shall furnish to the code official a signed and notarized statement from the grantee, transferee, mortgagee or lessee, acknowledging the receipt of such compliance order or notice of violation and fully accepting the responsibility without condition for making the corrections or repairs required by such compliance order or notice of violation.

SECTION 108 UNSAFE STRUCTURES AND EQUIPMENT

108.1 General. When a structure or equipment is found by the code official to be unsafe, or when a structure is found unfit for human occupancy, or is found unlawful, such structure shall be condemned pursuant to the provisions of this code.

108.1.1 Unsafe structures. An unsafe structure is one that is found to be dangerous to the life, health, property or safety of the public or the *occupants* of the structure by not providing minimum safeguards to protect or warn *occupants* in the event of fire, or because such structure contains unsafe equipment or is so damaged, decayed, dilapidated, structurally unsafe or of such faulty construction or unstable foundation, that partial or complete collapse is possible.

108.1.2 Unsafe equipment. Unsafe equipment includes any boiler, heating equipment, elevator, moving stairway, electrical wiring or device, flammable liquid containers or other equipment on the *premises* or within the structure which is in such disrepair or condition that such equipment is a hazard to life, health, property or safety of the public or occupants of the *premises* or structure.

108.1.3 Structure unfit for human occupancy. A structure is unfit for human occupancy whenever the code official finds that such structure is unsafe, unlawful or, because of the degree to which the structure is in disrepair or lacks maintenance, is insanitary, vermin or rat infested, contains filth and contamination, or lacks ventilation, illumination, sanitary or heating facilities or other essential equipment required by this code, or because the location of the structure constitutes a hazard to the occupants of the structure or to the public.

108.1.4 Unlawful structure. An unlawful structure is one found in whole or in part to be occupied by more persons than permitted under this code, or was erected, altered or occupied contrary to law.

108.1.5 Dangerous structure or premises. For the purpose of this code, any structure or premises that has any or all of the conditions or defects described below shall be considered dangerous:

- Any door, aisle, passageway, stairway, exit or other means of egress that does not conform to the approved building or fire code of the jurisdiction as related to the requirements for existing buildings.
- The walking surface of any aisle, passageway, stairway, exit or other means of egress is so warped, worn loose, torn or otherwise unsafe as to not provide safe and adequate means of egress.
- Any portion of a building, structure or appurtenance that has been damaged by fire, earthquake, wind, flood, deterioration, neglect, abandonment, vandalism or by any other cause to such an extent that it is

- likely to partially or completely collapse, or to become *detached* or dislodged.
- 4. Any portion of a building, or any member, appurtenance or ornamentation on the exterior thereof that is not of sufficient strength or stability, or is not so anchored, attached or fastened in place so as to be capable of resisting natural or artificial loads of one and one-half the original designed value.
- 5. The building or structure, or part of the building or structure, because of dilapidation, deterioration, decay, faulty construction, the removal or movement of some portion of the ground necessary for the support, or for any other reason, is likely to partially or completely collapse, or some portion of the foundation or underpinning of the building or structure is likely to fail or give way.
- 6. The building or structure, or any portion thereof, is clearly unsafe for its use and occupancy.
- 7. The building or structure is neglected, damaged, dilapidated, unsecured or abandoned so as to become an attractive nuisance to children who might play in the building or structure to their danger, becomes a harbor for vagrants, criminals or immoral persons, or enables persons to resort to the building or structure for committing a nuisance or an unlawful act.
 - 8. Any building or structure has been constructed, exists or is maintained in violation of any specific requirement or prohibition applicable to such building or structure provided by the approved building or fire code of the jurisdiction, or of any law or ordinance to such an extent as to present either a substantial risk of fire, building collapse or any other threat to life and safety.
- 9. A building or structure, used or intended to be used for dwelling purposes, hecause of inadequate maintenance, dilapidation, decay, damage, faulty construction or arrangement, inadequate light, ventilation, mechanical or plumbing system, or otherwise, is determined by the code official to be unsanitary, unfit for human habitation or in such a condition that is likely to cause sickness or disease.
 - 10. Any building or structure, because of a lack of sufficient or proper fire-resistance-rated construction, fire protection systems, electrical system, fuel connections, mechanical system, plumbing system or other cause, is determined by the code official to be a threat to life or health.
 - 11. Any portion of a building remains on a site after the demolition or destruction of the building or structure or whenever any building or structure is abandoned so as to constitute such building or portion thereof as an attractive nuisance or hazard to the public.

108.2 Closing of vacant structures. If the structure is vacant and unfit for human habitation and occupancy, and is not in danger of structural collapse, the code official is authorized to

post a placard of condemnation on the *premises* and order the structure closed up so as not to be an attractive nuisance. Upon failure of the *owner* to close up the *premises* within the time specified in the order, the *code official* shall cause the *premises* to be closed and secnred through any available public agency or by contract or arrangement by private persons and the cost thereof shall be charged against the real estate upon which the structure is located and shall be a lien upon such real estate and may be collected by any other legal resource.

108.2.1 Authority to disconnect service utilities. The code official shall have the authority to authorize disconnection of utility service to the building, structure or system regulated by this code and the referenced codes and standards set forth in Section 102.7 in case of emergency where necessary to eliminate an immediate hazard to life or property or when such utility connection has been made without approval. The code official shall notify the serving utility and, whenever possible, the owner and occupant of the building, structure or service system of the decision to disconnect prior to taking such action. If not notified prior to disconnection the owner or occupant of the building structure or service system shall be notified in writing as soon as practical thereafter.

108.3 Notice. Whenever the code official has condemned a structure or equipment under the provisions of this section, notice shall be posted in a conspicuous place in or about the structure affected by such notice and served on the owner or the person or persons responsible for the structure or equipment in accordance with Section 107.3. If the notice pertains to equipment, it shall also be placed on the condemned equipment. The notice shall be in the form prescribed in Section 107.2.

108.4 Placarding. Upon failure of the *owner* or person responsible to comply with the notice provisions within the time given, the *code official* shall post on the *premises* or on defective equipment a placard bearing the word "Condemned" and a statement of the penalties provided for occupying the *premises*, operating the equipment or removing the placard.

108.4.1 Placard removal. The code official shall remove the condemnation placard whenever the defect or defects upon which the condemnation and placarding action were based have been eliminated. Any person who defaces or removes a condemnation placard without the approval of the code official shall be subject to the penalties provided by this code.

108.5 Prohibited occupancy. Any occupied structure condemned and placarded by the code official shall be vacated as ordered by the code official. Any person who shall occupy a placarded premises or shall operate placarded equipment, and any owner or any person responsible for the premises who shall let anyone occupy a placarded premises or operate placarded equipment shall be liable for the penalties provided by this code.

108.6 Abatement methods. The owner, operator or occupant of a building, premises or equipment deemed unsafe by the code official shall abate or cause to be abated or corrected such unsafe conditions either by repair, rehabilitation, demolition or other approved corrective action.

108.7 Record. The *code official* shall canse a report to be filed on an nasafe condition. The report shall state the *occupancy* of the structure and the nature of the unsafe condition.

SECTION 109 EMERGENCY MEASURES

109.1 Imminent danger. When, in the opinion of the code official, there is imminent danger of failure or collapse of a building or structure which endangers life, or when any structure or part of a structure has fallen and life is endangered by the occupation of the structure, or when there is actual or potential danger to the building occupants or those in the proximity of any structure because of explosives, explosive fumes or vapors or the presence of toxic fumes, gases or materials, or operation of defective or dangerous equipment, the code official is hereby authorized and empowered to order and require the occupants to vacate the premises forthwith. The code official shall cause to be posted at each entrance to such structure a notice reading as follows: "This Structure Is Unsafe and Its Occupancy Has Been Prohibited by the Code Official." It shall be unlawful for any person to enter such structure except for the purpose of securing the structure, making the required repairs, removing the hazardous condition or of demolishing the same.

109.2 Temporary safeguards. Notwithstanding other provisions of this code, whenever, in the opinion of the code official, there is imminent danger due to an unsafe condition, the code official shall order the necessary work to be done, including the boarding up of openings, to render such structure temporarily safe whether or not the legal procedure herein described has been instituted; and shall cause such other action to be taken as the code official deems necessary to meet such emergency.

109.3 Closing streets. When necessary for public safety, the code official shall temporarily close structures and close, or order the authority having jurisdiction to close, sidewalks, streets, public ways and places adjacent to unsafe structures, and prohibit the same from being utilized.

109.4 Emergency repairs. For the purposes of this section, the code official shall employ the necessary labor and materials to perform the required work as expeditiously as possible.

109.5 Costs of emergency repairs. Costs incurred in the performance of emergency work shall be paid by the jurisdiction. The legal counsel of the jurisdiction shall institute appropriate action against the *owner* of the *premises* where the unsafe structure is or was located for the recovery of such costs.

109.6 Hearing. Any person ordered to take emergency measures shall comply with such order forthwith. Any affected person shall thereafter, upon petition directed to the appeals board, be afforded a hearing as described in this code.

SECTION 110 DEMOLITION

110.1 General. The code official shall order the owner of any premises upon which is located any structure, which in the code official judgment after review is so deteriorated or dilapidated or has become so out of repair as to be dangerous, unsafe, insanitary or otherwise unfit for human habitation or occu-

pancy, and such that it is unreasonable to repair the structure, to demolish and remove such structure; or if such structure is capable of being made safe by repairs, to repair and make safe and sanitary, or to board up and hold for future repair or to demolish and remove at the *owner's* option; or where there has been a cessation of normal construction of any structure for a period of more than two years, the *code official* shall order the *owner* to demolish and remove such structure, or board up until future repair. Boarding the huilding up for future repair shall not extend beyond one year, unless *approved* by the building official.

- **110.2 Notices and orders.** All notices and orders shall comply with Section 107.
- 110.3 Failure to comply. If the owner of a premises fails to comply with a demolition order within the time prescribed, the code official shall cause the structure to be demolished and removed, either through an available public agency or by contract or arrangement with private persons, and the cost of such demolition and removal shall be charged against the real estate upon which the structure is located and shall be a lien upon such real estate.
- 110.4 Salvage materials. When any structure has been ordered demolished and removed, the governing body or other designated officer under said contract or arrangement aforesaid shall have the right to sell the salvage and valuable materials at the highest price obtainable. The net proceeds of such sale, after deducting the expenses of such demolition and removal, shall be promptly remitted with a report of such sale or transaction, including the items of expense and the amounts deducted, for the person who is entitled thereto, subject to any order of a court. If such a surplns does not remain to be turned over, the report shall so state.

SECTION 111 MEANS OF APPEAL

- 111.1 Application for appeal. Any person directly affected by a decision of the *code official* or a notice or order issued under this code shall have the right to appeal to the board of appeals, provided that a written application for appeal is filed within 20 days after the day the decision, notice or order was served. An application for appeal shall be based on a claim that the true intent of this code or the rules legally adopted thereunder have been incorrectly interpreted, the provisions of this code do not fully apply, or the requirements of this code are adequately satisfied by other means.
- 111.2 Membership of board. The board of appeals shall consist of a minimum of three members who are qualified by experience and training to pass on matters pertaining to property maintenance and who are not employees of the jurisdiction. The code official shall be an ex-officio member hut shall have no vote on any matter before the board. The board shall be appointed by the chief appointing authority, and shall serve staggered and overlapping terms.
 - 111.2.1 Alternate members. The chief appointing authority shall appoint two or more alternate members who shall be called by the hoard chairman to hear appeals during the absence or disqualification of a member. Alternate mem-

- bers shall possess the qualifications required for board membership.
- 111.2.2 Chairman. The board shall annually select one of its members to serve as chairman.
- 111.2.3 Disqualification of member. A member shall not hear an appeal in which that member has a personal, professional or financial interest.
- 111.2.4 Secretary. The chief administrative officer shall designate a qualified person to serve as secretary to the board. The secretary shall file a detailed record of all proceedings in the office of the chief administrative officer.
- **111.2.5 Compensation of members.** Compensation of members shall be determined by law.
- 111.3 Notice of meeting. The board shall meet upon notice from the chairman, within 20 days of the filing of an appeal, or at stated periodic meetings.
- 111.4 Open hearing. All hearings before the board shall be open to the public. The appellant, the appellant's representative, the *code official* and any person whose interests are affected shall be given an opportunity to be heard. A quorum shall consist of not less than two-thirds of the board membership.
 - 111.4.1 Procedure. The board shall adopt and make available to the public through the secretary procedures under which a hearing will be conducted. The procedures shall not require compliance with strict rules of cyidence, but shall mandate that only relevant information be received.
- 111.5 Postponed hearing. When the full hoard is not present to hear an appeal, either the appellant or the appellant's representative shall have the right to request a postponement of the hearing.
- 111.6 Board decision. The board shall modify or reverse the decision of the *code official* only by a concurring vote of a majority of the total number of appointed board members.
 - 111.6.1 Records and copies. The decision of the board shall be recorded. Copies shall be furnished to the appellant and to the *code official*.
 - 111.6.2 Administration. The code official shall take immediate action in accordance with the decision of the board.
- 111.7 Court review. Any person, whether or not a previous party of the appeal, shall have the right to apply to the appropriate court for a writ of certiorari to correct errors of law. Application for review shall be made in the manner and time required by law following the filing of the decision in the office of the chief administrative officer.
- 111.8 Stays of enforcement. Appeals of notice and orders (other than *Imminent Danger* notices) shall stay the enforcement of the notice and order until the appeal is heard by the appeals board.

SECTION 112 STOP WORK ORDER

112.1 Authority. Whenever the *code official* finds any work regulated by this code being performed in a manner contrary to

the provisions of this code or in a dangerous or unsafe manner, the *code official* is authorized to issue a stop work order.

- 112.2 Issuance. A stop work order shall be in writing and shall be given to the *owner* of the property, to the *owner*'s agent, or to the person doing the work. Upon issuance of a stop work order, the cited work shall immediately cease. The stop work order shall state the reason for the order and the conditions under which the cited work is authorized to resume.
- 112.3 Emergencies. Where an emergency exists, the *code official* shall not be required to give a written notice prior to stopping the work.
- 112.4 Failure to comply. Any person who shall continue any work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be liable to a fine of not less than [AMOUNT] dollars or more than [AMOUNT] dollars.

DEFINITIONS

SECTION 201 GENERAL

201.1 Scope. Unless otherwise expressly stated, the following terms shall, for the purposes of this code, have the meanings shown in this chapter.

201.2 Interchangeability. Words stated in the present tense include the future; words stated in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural, the singular.

201.3 Terms defined in other codes. Where terms are not defined in this code and are defined in the International Building Code, International Fire Code, International Zoning Code, International Plumbing Code, International Mechanical Code or NFPA 70, such terms shall have the meanings ascribed to them as stated in those codes.

201.4 Terms not defined. Where terms are not defined through the methods authorized by this section, such terms shall have ordinarily accepted meanings such as the context implies.

201.5 Parts. Whenever the words "dwelling unit," "dwelling," "premises," "building," "rooming house," "rooming unit," "housekeeping unit" or "story" are stated in this code, they shall be construed as though they were followed by the words "or any part thereof."

SECTION 202 GENERAL DEFINITIONS

ANCHORED. Secured in a manner that provides positive connection.

APPROVED. Approved by the code official.

BASEMENT. That portion of a building which is partly or completely below grade.

BATHROOM. A room containing plumbing fixtures including a bathtub or shower,

BEDROOM. Any room or space used or intended to be used for sleeping purposes in either a dwelling or *sleeping unit*.

CODE OFFICIAL. The official who is eharged with the administration and enforcement of this code, or any duly authorized representative.

CONDEMN. To adjudge unfit for occupancy.

DETACHED. When a structural element is physically disconnected from another and that connection is necessary to provide a positive connection.

DETERIORATION. To weaken, disintegrate, corrode, rust or decay and lose effectiveness.

[B] DWELLING UNIT. A single unit providing complete, independent living facilities for one or more persons, including

permanent provisions for living, sleeping, eating, cooking and sanitation.

EASEMENT. That portion of land or property reserved for present or future use by a person or agency other than the legal fee *owner(s)* of the property. The *easement* shall be permitted to be for use uuder, on or above a said lot or lots.

EQUIPMENT SUPPORT. Those structural members or assemblies of members or manufactured elements, including braces, frames, lugs, snuggers, hangers or saddles, that transmit gravity load, lateral load and operating load between the equipment and the structure.

EXTERIOR PROPERTY. The open space on the *premises* and on adjoining property under the control of *owners* or *operators* of such *premises*.

GARBAGE. The animal or vegetable waste resulting from the handling, preparation, cooking and consumption of food.

GUARD. A building component or a system of building components located at or near the open sides of elevated walking surfaces that minimizes the possibility of a fall from the walking surface to a lower level.

HABITABLE SPACE. Space in a structure for living, sleeping, eating or cooking. *Bathrooms*, toilet rooms, closets, halls, storage or utility spaces, and similar areas are not considered habitable spaces.

HOUSEKEEPING UNIT. A room or group of rooms forming a single *habitable space* equipped and intended to be used for living, sleeping, cooking and eating which does not contain, within such a unit, a toilet, lavatory and bathtub or shower.

IMMINENT DANGER. A condition which could cause serious or life-threatening injury or death at any time.

INFESTATION. The presence, within or contiguous to, a structure or *premises* of insects, rats, vermin or other pests.

INOPERABLE MOTOR VEHICLE. A vehicle which cannot be driven upon the public streets for reason including but not limited to being unlicensed, wrecked, abandoned, in a state of disrepair, or incapable of being moved under its own power.

LABELED. Equipment, materials or products to which have been affixed a label, seal, symbol or other identifying mark of a nationally recognized testing laboratory, inspection agency or other organization concerned with product evaluation that maintains periodic inspection of the production of the above-labeled items and whose labeling indicates either that the equipment, material or product meets identified standards or has been tested and found suitable for a specified purpose.

LET FOR OCCUPANCY OR LET. To permit, provide or offer possession or occupancy of a dwelling, dwelling unit, rooming unit, building, premise or structure by a person who is or is not the legal owner of record thereof, pursuant to a written or unwritten lease, agreement or license, or pursuant to a

recorded or unrecorded agreement of contract for the sale of land.

NEGLECT. The lack of proper maintenance for a building or *structure*.

OCCUPANCY. The purpose for which a building or portion thereof is utilized or occupied.

OCCUPANT. Any individual living or sleeping in a building, or having possession of a space within a building.

OPENABLE AREA. That part of a window, skylight or door which is available for unobstructed *ventilation* and which opens directly to the outdoors.

OPERATOR. Any person who has charge, care or control of a structure or *premises* which is let or offered for *occupancy*.

OWNER. Any person, agent, operator, firm or corporation having a legal or equitable interest in the property; or recorded in the official records of the state, county or municipality as holding title to the property; or otherwise having control of the property, including the guardian of the estate of any such person, and the executor or administrator of the estate of such person if ordered to take possession of real property by a court.

PERSON. An individual, corporation, partnership or any other group acting as a unit.

PEST ELIMINATION. The control and elimination of insects, rodents or other pests by eliminating their harborage places; by removing or making inaccessible materials that serve as their food or water; by other approved pest elimination methods.

PREMISES. A lot, plot or parcel of land, easement or public way, including any structures thereon.

PUBLIC WAY. Any street, alley or similar parcel of land essentially unobstructed from the ground to the sky, which is deeded, dedicated or otherwise permanently appropriated to the public for public use.

ROOMING HOUSE. A building arranged or occupied for lodging, with or without meals, for compensation and not occupied as a one- or two-family dwelling.

ROOMING UNIT. Any room or group of rooms forming a single habitable unit occupied or intended to be occupied for sleeping or living, but not for cooking purposes.

RUBBISH. Combustible and noncombustible waste materials, except garbage; the term shall include the residue from the burning of wood, coal, coke and other combustible materials, paper, rags, cartons, boxes, wood, excelsior, rubber, leather, tree brauches, yard trimmings, tin cans, metals, mineral matter, glass, crockery and dust and other similar materials.

[B] SLEEPING UNIT. A room or space in which people sleep, which can also include permanent provisions for living, eating and either sanitation or kitchen facilities, but not both. Such rooms and spaces that are also part of a dwelling unit are not sleeping units.

STRICT LIABILITY OFFENSE. An offense in which the prosecution in a legal proceeding is not required to prove criminal intent as a part of its case. It is enough to prove that the

defendant either did an act which was prohibited, or failed to do an act which the defendant was legally required to do.

STRUCTURE. That which is built or constructed or a portion thereof.

TENANT. A person, corporation, partnership or group, whether or not the legal *owner* of record, occupying a building or portion thereof as a unit.

TOILET ROOM. A room containing a water closet or urinal but not a bathtub or shower.

ULTIMATE DEFORMATION. The deformation at which failure occurs and which shall be deemed to occur if the sustainable load reduces to 80 percent or less of the maximum strength.

VENTILATION. The natural or mechanical process of supplying conditioned or unconditioned air to, or removing such air from, any space.

WORKMANLIKE. Executed in a skilled manner; e.g., generally plumb, level, square, in line, undamaged and without marring adjacent work.

YARD. An open space on the same lot with a structure.

GENERAL REQUIREMENTS

SECTION 301 GENERAL

- **301.1 Scope.** The provisious of this chapter shall govern the minimum conditions and the responsibilities of persons for maintenance of structures, equipment and *exterior property*.
- 301.2 Responsibility. The owner of the premises shall maintain the structures and exterior property in compliance with these requirements, except as otherwise provided for in this code. A person shall not occupy as owner-occupant or permit another person to occupy premises which are not in a sanitary and safe condition and which do not comply with the requirements of this chapter. Occupants of a dwelling unit, rooming unit or housekeeping unit are responsible for keeping in a clean, sanitary and safe condition that part of the dwelling unit, rooming unit, housekeeping unit or premises which they occupy and control.
- 301.3 Vacant structures and land. All vacant structures and premises thereof or vacant land shall be maintained in a clean, safe, secure and sanitary condition as provided herein so as not to cause a blighting problem or adversely affect the public health or safety.

SECTION 302 EXTERIOR PROPERTY AREAS

- 302.1 Sanitation. All exterior property and premises shall be maintained in a clean, safe and sanitary condition. The occupant shall keep that part of the exterior property which such occupant occupies or controls in a clean and sanitary condition.
- **302.2 Grading and drainage.** All *premises* shall be graded and maintained to prevent the erosion of soil and to prevent the accumulation of stagnant water thereon, or within any structure located thereon.

Exception: Approved retention areas and reservoirs.

- **302.3 Sidewalks and driveways.** All sidewalks, walkways, stairs, driveways, parking spaces and similar areas shall be kept in a proper state of repair, and maintained free from hazardous conditions.
- 302.4 Weeds. All premises and exterior property shall be maintained free from weeds or plant growth in excess of (jurisdiction to insert height in inches). All noxious weeds shall be prohibited. Weeds shall be defined as all grasses, annual plants and vegetation, other than trees or shrubs provided; however, this term shall not include cultivated flowers and gardens.

Upon failure of the *owner* or agent having charge of a property to cut and destroy weeds after service of a notice of violation, they shall be subject to prosecution in accordance with Section 106.3 and as prescribed by the authority having jurisdiction. Upon failure to comply with the notice of violation, any duly authorized employee of the jurisdiction or contractor hired by the jurisdiction shall be authorized to enter upon the

property in violation and cut and destroy the weeds growing thereon, and the costs of such removal shall be paid by the *owner* or agent responsible for the property.

- 302.5 Rodent harborage. All structures and exterior property shall be kept free from rodent harborage and infestation. Where rodents are found, they shall be promptly exterminated by approved processes which will not be injurious to human health. After extermination, proper precautions shall be taken to eliminate rodent harborage and prevent reinfestation.
- 302.6 Exhaust vents. Pipes, ducts, conductors, fans or blowers shall not discharge gases, steam, vapor, hot air, grease, smoke, odors or other gaseous or particulate wastes directly upon abutting or adjacent public or private property or that of another tenant
- **302.7 Accessory structures.** All accessory structures, including *detached* garages, fences and walls, shall be maintained structurally sound and in good repair.
- **302.8 Motor vehicles.** Except as provided for in other regulations, no inoperative or unlicensed motor vehicle shall be parked, kept or stored on any *premises*, and no vehicle shall at any time be in a state of major disassembly, disrepair, or in the process of being stripped or dismantled. Painting of vehicles is prohibited unless conducted inside an *approved* spray booth.
 - **Exception:** A vehicle of any type is permitted to undergo major overhaul, including body work, provided that such work is performed iuside a structure or similarly enclosed area designed and *approved* for such purposes.
- 302.9 Defacement of property. No person shall willfully or wantonly damage, mutilate or deface any exterior surface of any structure or building on any private or public property by placing thereon any marking, carving or graffiti.

It shall be the responsibility of the owner to restore said surface to an approved state of maintenauce and repair.

SECTION 303 SWIMMING POOLS, SPAS AND HOT TUBS

- **303.1 Swimming pools.** Swimming pools shall be maintained in a clean and sanitary condition, and in good repair.
- 303.2 Enclosures. Private swimming pools, hot tubs and spas, containing water more than 24 inches (610 mm) in depth shall be completely surrounded by a fence or barrier at least 48 inches (1219 mm) in height above the finished ground level measured on the side of the barrier away from the pool. Gates and doors in such barriers shall be self-closing and self-latching. Where the self-latching device is less than 54 inches (1372 mm) above the bottom of the gate, the release mechanism shall be located on the pool side of the gate. Self-closing and self-latching gates shall be maintained such that the gate will positively close and latch when released from an open position of 6 inches (152 mm) from the gatepost. No existing pool enclosure

shall be removed, replaced or changed in a manner that reduces its effectiveness as a safety barrier.

Exception: Spas or hot tubs with a safety cover that complies with ASTM F 1346 shall be exempt from the provisions of this section.

SECTION 304 EXTERIOR STRUCTURE

304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound and sanitary so as not to pose a threat to the public health, safety or welfare.

304.1.1 Unsafe conditions. The following conditions shall be determined as unsafe and shall be repaired or replaced to comply with the *International Building Code* or the *International Existing Building Code* as required for existing buildings:

- The nominal strength of any structural member is exceeded by nominal loads, the load effects or the required strength;
- The anchorage of the floor or roof to walls or columns, and of walls and columns to foundations is not capable of resisting all nominal loads or load effects;
 - Structures or components thereof that have reached their limit state;
 - Siding and masonry joints including joints between the building envelope and the perimeter of windows, doors and skylights are not maintained, weather resistant or water tight;
 - Structural members that have evidence of deterioration or that are not capable of safely supporting all nominal loads and load effects;
 - Foundation systems that are not firmly supported by footings, are not plumb and free from open cracks and breaks, are not properly anchored or are not capable of supporting all nominal loads and resisting all load effects;
 - Exterior walls that are not anchored to supporting and supported elements or are not plumb and free of holes, cracks or breaks and loose or rotting materials, are not properly anchored or are not capable of supporting all nominal loads and resisting all load effects;
 - 8. Roofing or roofing components that have defects that admit rain, roof surfaces with inadequate drainage, or any portion of the roof framing that is not in good repair with signs of deterioration, fatigue or without proper anchorage and ineapable of supporting all nominal loads and resisting all load effects;
 - Flooring and flooring components with defects that
 affect serviceability or flooring components that
 show signs of deterioration or fatigue, are not properly anchored or are incapable of supporting all
 nominal loads and resisting all load effects;

- Veneer, cornices, belt courses, corbels, trim, wall
 facings and similar decorative features not properly
 anchored or that are anchored with connections not
 capable of supporting all nominal loads and resisting all load effects;
- 11. Overhang extensions or projections including, but not limited to, trash chutes, canopies, marquees, signs, awnings, fire escapes, standpipes and exhaust ducts not properly *anchored* or that are *anchored* with connections not capable of supporting all nominal loads and resisting all load effects;
- 12. Exterior stairs, decks, porches, balconies and all similar appurtenances attached thereto, including *guards* and handrails, are not structurally sound, not properly *anchored* or that are *anchored* with connections not capable of supporting all nominal loads and resisting all load effects; or
- 13. Chimneys, cooling towers, smokestacks and similar appurtenances not structurally sound or not properly *anchored*, or that are *anchored* with connections not capable of supporting all nominal loads and resisting all load effects.

Exceptions:

- 1. When substantiated otherwise by an approved method.
- Demolition of unsafe conditions shall be permitted when approved by the code official

304.2 Protective treatment. All exterior surfaces, including but not limited to, doors, door and window frames, cornices, porches, trim, balconies, decks and fences, shall be maintained in good condition. Exterior wood surfaces, other than decayresistant woods, shall be protected from the elements and decay by painting or other protective covering or treatment. Peeling, flaking and chipped paint shall be eliminated and surfaces repainted. All siding and masoury joints, as well as those between the building envelope and the perimeter of windows, doors and skylights, shall be maintained weather resistant and water tight. All metal surfaces subject to rust or corrosion shall be coated to inhibit such rust and corrosion, and all surfaces with rust or corrosion shall be stabilized and coated to inhibit future rust and corrosion. Oxidation stains shall be removed from exterior surfaces. Surfaces designed for stabilization by oxidation are exempt from this requirement.

[F] 304.3 Premises identification. Buildings shall have approved address numbers placed in a position to be plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. Address numbers shall be Arabie numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

304.4 Structural members. All structural members shall be maintained free from *deterioration*, and shall be capable of safely supporting the imposed dead and live loads.

304.5 Foundation walls. All foundation walls shall be maintained plumb and free from open cracks and breaks and shall be

kept in such condition so as to prevent the entry of rodents and other pests.

304.6 Exterior walls. All exterior walls shall be free from holes, breaks, and loose or rotting materials; and maintained weatherproof and properly surface coated where required to prevent *deterioration*.

304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or *deterioration* in the walls or interior portion of the structure. Roof drains, gutters and downspouts shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.

304.8 Decorative features. All cornices, belt courses, corbels, terra cotta trim, wall facings and similar decorative features shall be maintained in good repair with proper anchorage and in a safe condition.

304.9 Overhang extensions. All overhang extensions including, but not limited to canopies, marquees, signs, metal awnings, fire escapes, standpipes and exhaust ducts shall be maintained in good repair and be properly *anchored* so as to be kept in a sound condition. When required, all exposed surfaces of metal or wood shall be protected from the elements and against decay or rust by periodic application of weather-coating materials, such as paint or similar surface treatment.

304.10 Stairways, decks, porches and balconies. Every exterior stairway, deck, porch and balcony, and all appurtenances attached thereto, shall be maintained structurally sound, in good repair, with proper anchorage and capable of supporting the imposed loads.

304.11 Chimneys and towers. All chimneys, cooling towers, smoke stacks, and similar appurtenances shall be maintained structurally safe and sound, and in good repair. All exposed surfaces of metal or wood shall be protected from the elements and against decay or rust by periodic application of weather-coating materials, such as paint or similar surface treatment.

304.12 Handrails and guards. Every handrail and guard shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition.

304.13 Window, skylight and door frames. Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.

304.13.1 Glazing. All glazing materials shall be maintained free from cracks and holes.

304.13.2 Openable windows. Every window, other than a fixed window, shall be easily openable and capable of being held in position by window hardware.

304.14 Insect screens. During the period from [DATE] to [DATE], every door, window and other ontside opening required for *ventilation* of habitable rooms, food preparation areas, food service areas or any areas where products to be included or utilized in food for human consumption are processed, manufactured, packaged or stored shall be supplied with *approved* tightly fitting screens of not less than 16 mesh per inch (16

mesh per 25 mm), and every screen door used for insect control shall have a self-closing device in good working condition.

Exception: Screens shall not be required where other approved means, such as air curtains or insect repellent fans, are employed.

304.15 Doors. All exterior doors, door assemblies and hardware shall be maintained in good condition. Locks at all entrances to dwelling units and sleeping units shall tightly secure the door. Locks on means of egress doors shall be in accordance with Section 702.3.

304.16 Basement hatchways. Every *basement* hatchway shall be maintained to prevent the entrance of rodents, rain and surface drainage water.

304.17 Guards for basement windows. Every *basement* window that is openable shall be supplied with rodent shields, storm windows or other *approved* protection against the entry of rodents.

304.18 Building security. Doors, windows or hatchways for dwelling units, room units or housekeeping units shall be provided with devices designed to provide security for the occupants and property within.

304.18.1 Doors. Doors providing access to a dwelling unit, rooming unit or housekeeping unit that is rented, leased or let shall be equipped with a deadbolt lock designed to be readily openable from the side from which egress is to be made without the need for keys, special knowledge or effort and shall have a lock throw of not less than 1 inch (25 mm). Such deadbolt locks shall be installed according to the manufacturer's specifications and maintained in good working order. For the purpose of this section, a sliding bolt shall not be considered an acceptable deadbolt lock.

304.18.2 Windows. Operable windows located in whole or in part within 6 feet (1828 mm) above ground level or a walking surface below that provide access to a dwelling unit, rooming unit or housekeeping unit that is rented, leased or let shall be equipped with a window sash locking device.

304.18.3 Basement hatchways. Basement hatchways that provide access to a dwelling unit, rooming unit or house-keeping unit that is rented, leased or let shall be equipped with devices that secure the units from unauthorized entry.

SECTION 305 INTERIOR STRUCTURE

305.1 General. The interior of a structure and equipment therein shall be maintained in good repair, structurally sound and in a sanitary condition. Occupants shall keep that part of the structure which they occupy or control in a clean and sanitary condition. Every owner of a structure containing a rooming house, housekeeping units, a hotel, a dormitory, two or more dwelling units or two or more nonresidential occupancies, shall maintain, in a clean and sanitary condition, the shared or public areas of the structure and exterior property.

305.1.1 Unsafe conditions. The following conditions shall be determined as ansafe and shall be repaired or replaced to comply with the *International Building Code* or the *Inter-*

national Existing Building Code as required for existing buildings:

- 1. The nominal strength of any structural member is exceeded by nominal loads, the load effects or the required strength;
 - 2. The anchorage of the floor or roof to walls or columns, and of walls and columns to foundations is not capable of resisting all nominal loads or load effects;
 - 3. Structures or components thereof that have reached their limit state:
 - 4. Structural members are incapable of supporting nominal loads and load effects;
- 5. Stairs, landings, balconies and all similar walking surfaces, including guards and handrails, are not structurally sound, not properly anchored or are anchored with connections not capable of supporting all nominal loads and resisting all load effects;
- 6. Foundation systems that are not firmly supported by footings are not plumb and free from open cracks and breaks, are not properly anchored or are not capable of supporting all nominal loads and resisting all load effects.

Exceptions:

- I. When substantiated otherwise by an approved method.
- 2. Demolition of unsafe conditions shall be permitted when approved by the code official.
- 305.2 Structural members. All structural members shall be maintained structurally sound, and be capable of supporting the imposed loads.
- 305.3 Interior surfaces. All interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking or abraded paint shall be repaired, removed or covered. Cracked or loose plaster, decayed wood and other defective surface conditions shall be corrected.
- 305.4 Stairs and walking surfaces. Every stair, ramp, landing, balcony, porch, deck or other walking surface shall be maintained in sound condition and good repair.
- 305.5 Handrails and guards. Every handrail and guard shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition.
- **305.6 Interior doors.** Every interior door shall fit reasonably well within its frame and shall be capable of being opened and closed by being properly and securely attached to jambs, headers or tracks as intended by the manufacturer of the attachment hardware.

않으면 많은 프로그리트 그런 그리고 됩니다. 그런

SECTION 306 COMPONENT SERVICEABILITY

- 306.1 General. The components of a structure and equipment therein shall be maintained in good repair, structurally sound and in a sanitary condition.
 - 306.1.1 Unsafe conditions. Where any of the following conditions eause the component or system to be beyond its limit state, the component or system shall be determined as unsafe and shall be repaired or replaced to comply with the International Building Code as required for existing buildings:
 - 1. Soils that have been subjected to any of the following conditions:
 - 1.1. Collapse of footing or foundation system;
 - 1.2. Damage to footing, foundation, concrete or other structural element due to soil expan-
 - 1.3. Adverse effects to the design strength of footing, foundation, concrete or other structural element due to a chemical reaction from the soil;
 - 1.4. Inadequate soil as determined by a geotechnical investigation;
 - 1.5. Where the allowable bearing capacity of the soil is in doubt; or
 - 1.6. Adverse effects to the footing, foundation, concrete or other structural element due to the ground water table.
 - 2. Concrete that has been subjected to any of the following conditions:
 - 2.1. Deterioration;
 - 2.2. Ultimate deformation;
 - 2.3. Fractures;
 - 2.4. Fissures:

 - 2.5. Spalling; 2.6. Exposed reinforcement; or
 - 2.7. Detached, dislodged or failing connections.
 - 3. Aluminum that has been subjected to any of the following conditions:
 - 3.1. Deterioration;
 - 3.2. Corrosion:
 - 3.3. Elastic deformation;
 - 3.4. Ultimate deformation;
 - 3.5. Stress or strain cracks;
 - 3.6. Joint fatigue; or
 - 3.7. Detached, dislodged or failing connections.

- 4. Masonry that has been subjected to any of the following conditions:
 - 4.1. Deterioration;
 - 4.2. Ultimate deformation;
 - 4.3. Fractures in masonry or mortar joints;
 - 4.4. Fissures in masonry or mortar joints;
 - 4.5. Spalling;
 - 4.6. Exposed reinforcement; or
 - 4.7. Detached, dislodged or failing connections.
- 5. Steel that has been subjected to any of the following conditions:
 - 5.1. Deterioration;
 - 5.2. Elastic deformation;
 - 5.3. Ultimate deformation;
 - 5.4. Metal fatigue; or
 - 5.5. Detached, dislodged or failing connections.
- 6. Wood that has been subjected to any of the following conditions:
 - 6.1. Ultimate deformation;
 - 6.2. Deterioration;
 - 6.3. Damage from insects, rodents and other vermin;
 - 6.4. Fire damage beyond charring;
 - 6.5. Significant splits and checks;
 - 6.6, Horizontal shear cracks;
 - 6.7. Vertical shear cracks;
 - 6.8. Inadequate support;
 - Detached, dislodged or failing connections;
 or
 - 6.10. Excessive cutting and notching.

Exceptions:

- When substantiated otherwise by an approved method.
- 2. Demolition of unsafe conditions shall be permitted when approved by the code official.

SECTION 307 HANDRAILS AND GUARDRAILS

307.1 General. Every exterior and interior flight of stairs having more than four risers shall have a handrail on one side of the stair and every open portion of a stair, landing, balcony, porch, deck, ramp or other walking surface which is more than 30 inches (762 mm) above the floor or grade below shall have guards. Handrails shall not be less than 30 inches (762 mm) high or more than 42 inches (1067 mm) high measured vertically above the nosing of the tread or above the finished floor of the landing or walking surfaces. Guards shall not be less than

30 inches (762 mm) high above the floor of the landing, balcony, porch, deck, or ramp or other walking surface.

Exception: Guards shall not be required where exempted by the adopted building code.

SECTION 308 RUBBISH AND GARBAGE

308.1 Accumulation of rubbish or garbage. All exterior property and premises, and the interior of every structure, shall be free from any accumulation of rubbish or garbage.

308.2 Disposal of rubbish. Every *occupant* of a structure shall dispose of all *rubbish* in a clean and sanitary manner by placing such *rubbish* in *approved* containers.

308.2.1 Rubbish storage facilities. The owner of every occupied premises shall supply approved covered containers for rubbish, and the owner of the premises shall be responsible for the removal of rubbish.

308.2.2 Refrigerators. Refrigerators and similar equipment not in operation shall not be discarded, abandoned or stored on *premises* without first removing the doors.

308.3 Disposal of garbage. Every occupant of a structure shall dispose of garbage in a clean and sanitary manner by placing such garbage in an approved garbage disposal facility or approved garbage containers.

308.3.1 Garbage facilities. The owner of every dwelling shall supply one of the following: an approved mechanical food waste grinder in each dwelling unit; an approved incinerator unit in the structure available to the occupants in each dwelling unit; or an approved leakproof, covered, outside garbage container.

308.3.2 Containers. The operator of every establishment producing garbage shall provide, and at all times cause to be utilized, approved leakproof containers provided with close-fitting covers for the storage of such materials until removed from the premises for disposal.

SECTION 309 PEST ELIMINATION

309.1 Infestation. All structures shall be kept free from insect and rodent *infestation*. All structures in which insects or rodents are found shall be promptly exterminated by *approved* processes that will not be injurious to human health. After extermination, proper precautions shall be taken to prevent reinfestation.

309.2 Owner. The *owner* of any structure shall be responsible for extermination within the structure prior to renting or leasing the structure.

309.3 Single occupant. The *occupant* of a one-family dwelling or of a single-*tenant* nonresidential structure shall be responsible for extermination on the *premises*.

309.4 Multiple occupancy. The *owner* of a structure containing two or more *dwelling units*, a multiple *occupancy*, a *rooming house* or a nonresidential structure shall be responsible for

extermination in the public or shared areas of the structure and exterior property. If infestation is caused by failure of an occupant to prevent such infestation in the area occupied, the occupant and owner shall be responsible for extermination.

309.5 Occupant. The occupant of any structure shall be responsible for the continued rodent and pest-free condition of the structure.

Exception: Where the *infestations* are caused by defects in the structure, the *owner* shall be responsible for extermination

Seeks that he has a low property or you. We all fittings has have parted it. Will

COLUMN TO SHEET AND ADMITTACK BELLINGS SECTION ASSESSMENT AS 2014

THE RESIDENCE OF STREET SHEET, LAND

with the contract of the contr

weeks a control of the second of the second

The second of the last section will be the section of J. Sec.

that of the received it will be a state of the last received

And the second section of the second second

application in the contraction of the residence of

In the second second

to the second reduction of the

School Support Spectral Sci.

Secretary and a second line

Separate Statement S. J.

2009 INTERNATIONAL PROPERTY MAINTENANCE CODE®

LIGHT, VENTILATION AND OCCUPANCY LIMITATIONS

SECTION 401 GENERAL

- **401.1 Scope.** The provisions of this chapter shall govern the minimum conditions and standards for light, *ventilation* and space for occupying a structure.
- **401.2 Responsibility.** The *owner* of the structure shall provide and maintain light, *ventilation* and space conditions in compliance with these requirements. A person shall not occupy as *owner-occupant*, or permit another person to occupy, any *premises* that do not comply with the requirements of this chapter.
- **401.3** Alternative devices. In lieu of the means for natural light and ventilation herein prescribed, artificial light or mechanical ventilation complying with the International Building Code shall be permitted.

SECTION 402

402.1 Habitable spaces. Every habitable space shall have at least one window of approved size facing directly to the outdoors or to a court. The minimum total glazed area for every habitable space shall be 8 percent of the floor area of such room. Wherever walls or other portions of a structure face a window of any room and such obstructions are located less than 3 feet (914 mm) from the window and extend to a level above that of the ceiling of the room, such window shall not be deemed to face directly to the outdoors nor to a court and shall not be included as contributing to the required minimum total window area for the room.

Exception: Where natural light for rooms or spaces without exterior glazing areas is provided through an adjoining room, the unobstructed opening to the adjoining room shall be at least 8 percent of the floor area of the interior room or space, but not less than 25 square feet (2.33 m²). The exterior glazing area shall be based on the total floor area being served.

- 402.2 Common halls and stairways. Every common hall and stairway in residential occupancies, other than in one- and two-family dwellings, shall be lighted at all times with at least a 60-watt standard incandescent light bulb for each 200 square feet (19 m²) of floor area or equivalent illumination, provided that the spacing between lights shall not be greater than 30 feet (9144 mm). In other than residential occupancies, means of egress, including exterior means of egress, stairways shall be illuminated at all times the building space served by the means of egress is occupied with a minimum of 1 footcandle (11 lux) at floors, landings and treads.
- **402.3** Other spaces. All other spaces shall be provided with natural or artificial light sufficient to permit the maintenance of sanitary conditions, and the safe *occupancy* of the space and utilization of the appliances, equipment and fixtures.

SECTION 403 VENTILATION

403.1 Habitable spaces. Every habitable space shall have at least one openable window. The total openable area of the window in every room shall be equal to at least 45 percent of the minimum glazed area required in Section 402.1.

Exception: Where rooms and spaces without openings to the outdoors are ventilated through an adjoining room, the unobstructed opening to the adjoining room shall be at least 8 percent of the floor area of the interior room or space, but not less than 25 square feet (2.33 m²). The ventilation openings to the outdoors shall be based on a total floor area being ventilated.

403.2 Bathrooms and toilet rooms. Every bathroom and toilet room shall comply with the ventilation requirements for habitable spaces as required by Section 403.1, except that a window shall not be required in such spaces equipped with a mechanical ventilation system. Air exhausted by a mechanical ventilation system from a bathroom or toilet room shall discharge to the outdoors and shall not be recirculated.

403.3 Cooking facilities. Unless approved through the certificate of occupancy, cooking shall not be permitted in any rooming unit or dormitory unit, and a cooking facility or appliance shall not be permitted to be present in the rooming unit or dormitory unit.

Exceptions:

- 1. Where specifically approved in writing by the code official.
- 2. Devices such as coffee pots and microwave ovens shall not be considered cooking appliances.
- 403.4 Process ventilation. Where injurious, toxic, irritating or noxious fumes, gases, dusts or mists are generated, a local exhaust *ventilation* system shall be provided to remove the contaminating agent at the source. Air shall be exhausted to the exterior and not be recirculated to any space.
- 403.5 Clothes dryer exhaust. Clothes dryer exhaust systems shall be independent of all other systems and shall be exhausted outside the structure in accordance with the manufacturer's instructions.

Exception: Listed and *labeled* condensing (ductless) clothes dryers.

SECTION 404 OCCUPANCY LIMITATIONS

404.1 Privacy. Dwelling units, hotel units, housekeeping units, rooming units and dormitory units shall be arranged to provide privacy and be separate from other adjoining spaces.

404.2 Minimum room widths. A habitable room, other than a kitchen, shall not be less than 7 feet (2134 mm) in any plan dimension. Kitchens shall have a clear passageway of not less than 3 feet (914 mm) between counterfronts and appliances or counterfronts and walls.

404.3 Minimum ceiling heights. Habitable spaces, hallways, corridors, laundry areas, bathrooms, toilet rooms and habitable basement areas shall have a clear ceiling height of not less than 7 feet (2134 mm).

Exceptions:

- 1. In one- and two-family dwellings, beams or girders spaced not less than 4 feet (1219 mm) on center and projecting not more than 6 inches (152 mm) below the required ceiling height.
- 2. Basement rooms in one- and two-family dwellings occupied exclusively for laundry, study or recreation purposes, having a ceiling height of not less than 6 feet 8 inches (2033 mm) with not less than 6 feet 4 inches (1932 mm) of clear height under beams, girders, ducts and similar obstructions.
- 3. Rooms occupied exclusively for sleeping, study or similar purposes and having a sloped ceiling over all or part of the room, with a clear ceiling height of at least 7 feet (2134 mm) over not less than one-third of the required minimum floor area. In calculating the floor area of such rooms, only those portions of the floor area with a clear ceiling height of 5 feet (1524 mm) or more shall be included.
- **404.4 Bedroom and living room requirements.** Every *bedroom* and living room shall comply with the requirements of Sections 404.4.1 through 404.4.5.
 - **404.4.1 Room area.** Every living room shall contain at least 120 square feet (11.2 m²) and every *bedroom* shall contain at least 70 square feet (6.5 m²).
 - **404.4.2** Access from bedrooms. Bedrooms shall not constitute the only means of access to other bedrooms or habitable spaces and shall not serve as the only means of egress from other habitable spaces.

Exception: Units that contain fewer than two bedrooms.

404.4.3 Water closet accessibility. Every bedroom shall have access to at least one water closet and one lavatory without passing through another bedroom. Every bedroom in a dwelling unit shall have access to at least one water closet and lavatory located in the same story as the bedroom or an adjacent story.

404.4.4 Prohibited occupancy. Kitchens and nonhabitable spaces shall not be used for sleeping purposes.

404.4.5 Other requirements. Bedrooms shall comply with the applicable provisions of this code including, but not limited to, the light, ventilation, room area, ceiling height and room width requirements of this chapter; the plumbing facilities and water-heating facilities requirements of Chapter 5; the heating facilities and electrical receptacle requirements of Chapter 6; and the smoke detector and emergency escape requirements of Chapter 7.

404.5 Overcrowding. The number of persons occupying a dwelling unit shall not create conditions that, in the opinion of the code official, endanger the life, health, safety or welfare of the occupants.

404.6 Efficiency unit. Nothing in this section shall prohibit an efficiency living unit from meeting the following requirements:

- A unit occupied by not more than two occupants shall have a clear floor area of not less than 220 square feet (20.4 m²). A unit occupied by three occupants shall have a clear floor area of not less than 320 square feet (29.7 m²). These required areas shall be exclusive of the areas required by Items 2 and 3.
- 2. The unit shall be provided with a kitchen sink, cooking appliance and refrigeration facilities, each having a clear working space of not less than 30 inches (762 mm) in front. Light and ventilation conforming to this code shall be provided.
- The unit shall be provided with a separate bathroom containing a water closet, lavatory and bathtub or shower.
- 4. The maximum number of occupants shall be three.

404.7 Food preparation. All spaces to be occupied for food preparation purposes shall contain suitable space and equipment to store, prepare and serve foods in a sanitary manner. There shall be adequate facilities and services for the sanitary disposal of food wastes and refuse, including facilities for temporary storage.

PLUMBING FACILITIES AND FIXTURE REQUIREMENTS

SECTION 501 GENERAL

501.1 Scope. The provisions of this chapter shall govern the minimum plumbing systems, facilities and plumbing fixtures to be provided.

501.2 Responsibility. The *owner* of the structure shall provide and maintain such plumbing facilities and plumbing fixtures in compliance with these requirements. A person shall not occupy as *owner-occupant* or permit another person to occupy any structure or *premises* which does not comply with the requirements of this chapter.

[P] SECTION 502 REQUIRED FACILITIES

502.1 Dwelling units. Every dwelling unit shall contain its own bathtub or shower, lavatory, water closet and kitchen sink which shall be maintained in a sanitary, safe working condition. The lavatory shall be placed in the same room as the water closet or located in close proximity to the door leading directly into the room in which such water closet is located. A kitchen sink shall not be used as a substitute for the required lavatory.

502.2 Rooming houses. At least one water closet, lavatory and bathtub or shower shall be supplied for each four *rooming units*.

502.3 Hotels. Where private water closets, lavatories and baths are not provided, one water closet, one lavatory and one bathtub or shower having access from a public hallway shall be provided for each ten *occupants*.

502.4 Employees' facilities. A minimum of one water closet, one lavatory and one drinking facility shall be available to employees.

502.4.1 Drinking facilities. Drinking facilities shall be a drinking fountain, water cooler, bottled water cooler or disposable cups next to a sink or water dispenser. Drinking facilities shall not be located in *toilet rooms* or *bathrooms*.

502.5 Public toilet facilities. Public toilet facilities shall be maintained in a safe sanitary and working condition in accordance with the *International Plumbing Code*. Except for periodic maintenance or cleaning, public access and use shall be provided to the toilet facilities at all times during occupancy of the *premises*.

[P] SECTION 503 TOILET ROOMS

503.1 Privacy. Toilet rooms and bathrooms shall provide privacy and shall not constitute the only passageway to a hall or other space, or to the exterior. A door and interior locking device shall be provided for all common or shared bathrooms and toilet rooms in a multiple dwelling.

503.2 Location. Toilet rooms and bathrooms serving hotel units, rooming units or dormitory units or housekeeping units, shall have access by traversing not more than one flight of stairs and shall have access from a common hall or passageway.

503.3 Location of employee toilet facilities. Toilet facilities shall have access from within the employees' working area. The required toilet facilities shall be located not more than one story above or below the employees' working area and the path of travel to such facilities shall not exceed a distance of 500 feet (152 m). Employee facilities shall either be separate facilities or combined employee and public facilities.

Exception: Facilities that are required for employees in storage structures or kiosks, which are located in adjacent structures under the same ownership, lease or control, shall not exceed a travel distance of 500 feet (152 m) from the employees' regular working area to the facilities.

503.4 Floor surface. In other than dwelling units, every toilet room floor shall be maintained to be a smooth, hard, nonabsorbent surface to permit such floor to be easily kept in a clean and sanitary condition.

[P] SECTION 504 PLUMBING SYSTEMS AND FIXTURES

504.1 General. All plumbing fixtures shall be properly installed and maintained in working order, and shall be kept free from obstructions, leaks and defects and be capable of performing the function for which such plumbing fixtures are designed. All plumbing fixtures shall be maintained in a safe, sanitary and functional condition.

504.2 Fixture clearances. Plumbing fixtures shall have adequate clearances for usage and cleaning.

504.3 Plumbing system hazards. Where it is found that a plumbing system in a structure constitutes a hazard to the occupants or the structure by reason of inadequate service, inadequate venting, cross connection, backsiphonage, improper installation, deterioration or damage or for similar reasons, the code official shall require the defects to he corrected to eliminate the hazard.

SECTION 505 WATER SYSTEM

505.1 General. Every sink, lavatory, bathtub or shower, drinking fountain, water closet or other plumbing fixture shall be properly connected to either a public water system or to an approved private water system. All kitchen sinks, lavatories, laundry facilities, hathtubs and showers shall be supplied with hot or tempered and cold running water in accordance with the International Plumbing Code.

[P] 505.2 Contamination. The water supply shall be maintained free from contamination, and all water inlets for plumb-

ing fixtures shall be located above the flood-level rim of the fixture. Shampoo basin faucets, janitor sink faucets and other hose bibs or faucets to which hoses are attached and left in place, shall be protected by an approved atmospheric-type vacuum breaker or an approved permanently attached hose connection vacuum breaker.

505.3 Supply. The water supply system shall be installed and maintained to provide a supply of water to plumbing fixtures, devices and appurtenances in sufficient volume and at pressures adequate to enable the fixtures to function properly, safely, and free from defects and leaks.

505.4 Water heating facilities. Water heating facilities shall be properly installed, maintained and capable of providing an adequate amount of water to be drawn at every required sink, lavatory, bathtub, shower and laundry facility at a temperature of not less than 110°F (43°C). A gas-burning water heater shall not be located in any bathroom, toilet room, bedroom or other occupied room normally kept closed, unless adequate combustion air is provided. An approved combination temperature and pressure-relief valve and relief valve discharge pipe shall be properly installed and maintained on water heaters.

[P] SECTION 506 SANITARY DRAINAGE SYSTEM

506.1 General. All plumbing fixtures shall be properly connected to either a public sewer system or to an *approved* private sewage disposal system.

506.2 Maintenance. Every plumbing stack, vent, waste and sewer line shall function properly and be kept free from obstructions, leaks and defects.

506.3 Grease interceptors. Where it has been determined that a grease interceptor is not being maintained and serviced as intended by this code and the manufacturer's instructions, an approved interceptor monitoring system shall be provided or a maintenance program shall be established with documentation submitted to the code official.

[P] SECTION 507 STORM DRAINAGE

507.1 General. Drainage of roofs and paved areas, *yards* and courts, and other open areas on the *premises* shall not be discharged in a manner that creates a public nuisance.

MECHANICAL AND ELECTRICAL REQUIREMENTS

SECTION 601 GENERAL

The street was a street of the

601.1 Scope. The provisions of this chapter shall govern the minimum mechanical and electrical facilities and equipment to be provided.

601.2 Responsibility. The owner of the structure shall provide and maintain mechanical and electrical facilities and equipment in compliance with these requirements. A person shall not occupy as owner-occupant or permit another person to occupy any premises which does not comply with the requirements of this chapter.

SECTION 602 HEATING FACILITIES

602.1 Facilities required. Heating facilities shall be provided in structures as required by this section.

602.2 Residential occupancies. Dwellings shall be provided with heating facilities capable of maintaining a room temperature of 68°F (20°C) in all habitable rooms, bathrooms and toilet rooms based on the winter outdoor design temperature for the locality indicated in Appendix D of the International Plumbing Code. Cooking appliances shall not be used to provide space heating to meet the requirements of this section.

Exception: In areas where the average monthly temperature is above 30°F (-1°C), a minimum temperature of 65°F (18°C) shall be maintained.

602.3 Heat supply. Every owner and operator of any building who rents, leases or lets one or more dwelling units or sleeping units on terms, either expressed or implied, to furnish heat to the occupants thereof shall supply heat during the period from [DATE] to [DATE] to maintain a temperature of not less than 68°F (20°C) in all habitable rooms, bathrooms and toilet rooms.

Exceptions:

- When the outdoor temperature is below the winter outdoor design temperature for the locality, maintenance of the minimum room temperature shall not be required provided that the heating system is operating at its full design capacity. The winter outdoor design temperature for the locality shall be as indicated in Appendix D of the International Plumbing Code.
 - In areas where the average monthly temperature is above 30°F (-1°C) a minimum temperature of 65°F (18°C) shall be maintained.
- 602.4 Occupiable work spaces. Indoor occupiable work spaces shall be supplied with heat during the period from

[DATE] to [DATE] to maintain a temperature of not less than 65°F (18°C) during the period the spaces are occupied.

Exceptions:

- 1. Processing, storage and operation areas that require cooling or special temperature conditions.
- Areas in which persons are primarily engaged in vigorous physical activities.

602.5 Room temperature measurement. The required room temperatures shall be measured 3 feet (914 mm) above the floor near the center of the room and 2 feet (610 mm) inward from the center of each exterior wall.

SECTION 603 MECHANICAL EQUIPMENT

603.1 Mechanical appliances. All mechanical appliances, fireplaces, solid fuel-burning appliances, cooking appliances and water heating appliances shall be properly installed and maintained in a safe working condition, and shall be capable of performing the intended function.

603.2 Removal of combustion products. All fuel-burning equipment and appliances shall be connected to an *approved* chimney or vent.

Exception: Fuel-burning equipment and appliances which are *labeled* for unvented operation.

- **603.3** Clearances. All required clearances to combustible materials shall be maintained.
- 603.4 Safety controls. All safety controls for fuel-burning equipment shall be maintained in effective operation.
- 603.5 Combustion air. A supply of air for complete combustion of the fuel and for *ventilation* of the space containing the fuel-burning equipment shall be provided for the fuel-burning equipment.
- **603.6** Energy conservation devices. Devices intended to reduce fuel consumption by attachment to a fuel-burning appliance, to the fuel supply line thereto, or to the vent outlet or vent piping therefrom, shall not be installed unless *labeled* for such purpose and the installation is specifically *approved*.

SECTION 604 ELECTRICAL FACILITIES

604.1 Facilities required. Every occupied building shall be provided with an electrical system in compliance with the requirements of this section and Section 605.

604.2 Service. The size and usage of appliances and equipment shall serve as a basis for determining the need for additional

facilities in accordance with NFPA 70. Dwelling units shall be served by a three-wire, 120/240 volt, single-phase electrical service having a rating of not less than 60 amperes.

604.3 Electrical system bazards. Where it is found that the electrical system in a structure constitutes a hazard to the occupants or the structure by reason of inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, deterioration or damage, or for similar reasons, the code official shall require the defects to be corrected to eliminate the hazard.

604.3.1 Abatement of electrical hazards associated with water exposure. The provisions of this section shall govern the repair and replacement of electrical systems and equipment that have been exposed to water.

604.3.1.1 Electrical equipment. Electrical distribution equipment, motor circuits, power equipment, transformers, wire, cable, flexible cords, wiring devices, ground fault circuit interrupters, surge protectors, molded case circuit breakers, low-voltage fuses, luminaires, ballasts, motors and electronic control, signaling and communication equipment that have been exposed to water shall be replaced in accordance with the provisions of the *International Building Code*.

Exception: The following equipment shall be allowed to be repaired where an inspection report from the equipment manufacturer or approved manufacturer's representative indicates that the equipment has not sustained damage that requires replacement:

- 1. Enclosed switches, rated 600 volts or less;
- 2. Busway, rated 600 volts or less;
- 3. Panelboards, rated 600 volts or less;
- 4. Switchboards, rated 600 volts or less;
- 5. Fire pump controllers, rated 600 volts or less;
- 6. Manual and magnetic motor controllers;
- 7. Motor control centers;
- 8. Alternating current high-voltage circuit breakers;
- Low-voltage power circuit breakers;
- Protective relays, meters and current transformers;
- 11. Low- and medium-voltage switchgear;
- 12. Liquid-filled transformers;
- 13. Cast-resin transformers;
- 14. Wire or cable that is suitable for wet locations and whose ends have not been exposed to water;
- 15. Wire or cable, not containing fillers, that is suitable for wet locations and whose ends have not been exposed to water;
- 16. Luminaires that are listed as submersible;
- 17. Motors;

- Electronic control, signaling and communication equipment.
- 604.3.2 Abatement of electrical hazards associated with fire exposure. The provisions of this section shall govern the repair and replacement of electrical systems and equipment that have been exposed to fire.

604.3.2.1 Electrical equipment. Electrical switches, receptacles and fixtures, including furnace, water heating, security system and power distribution circuits, that have been exposed to fire, shall be replaced in accordance with the provisions of the *International Building Code*.

Exception: Electrical switches, receptacles and fixtures that shall be allowed to be repaired where an inspection report from the equipment manufacturer or approved manufacturer's representative indicates that the equipment has not sustained damage that requires replacement.

SECTION 605 ELECTRICAL EQUIPMENT

605.1 Installation. All electrical equipment, wiring and appliances shall be properly installed and maintained in a safe and approved manner.

605.2 Receptacles. Every habitable space in a dwelling shall contain at least two separate and remote receptacle outlets. Every laundry area shall contain at least one grounded-type receptacle or a receptacle with a ground fault circuit interrupter. Every bathroom shall contain at least one receptacle. Any new bathroom receptacle outlet shall have ground fault circuit interrupter protection.

605.3 Luminaires. Every public hall, interior stairway, toilet room, kitchen, bathroom, laundry room, boiler room and furnace room shall contain at least one electric luminaire.

SECTION 606 ELEVATORS, ESCALATORS AND DUMBWAITERS

606.1 General. Elevators, dumbwaiters and escalators shall be maintained in compliance with ASME A17.1. The most current certificate of inspection shall be on display at all times within the elevator or attached to the escalator or dumbwaiter, be available for public inspection in the office of the building operator or be posted in a publicly conspicuous location approved by the code official. The inspection and tests shall be performed at not less than the periodic intervals listed in ASME A17.1, Appendix N, except where otherwise specified by the authority having jurisdiction.

606.2 Elevators: In buildings equipped with passeuger elevators, at least one elevator shall be maintained in operation at all times when the building is occupied.

Exception: Buildings equipped with only one elevator shall be permitted to have the elevator temporarily out of service for testing or servicing.

SECTION 607 DUCT SYSTEMS

607.1 General. Duct systems shall be maintained free of obstructions and shall be capable of performing the required function.

FIRE SAFETY REQUIREMENTS

SECTION 701 GENERAL

701.1 Scope. The provisions of this chapter shall govern the minimum conditions and standards for fire safety relating to structures and exterior *premises*, including fire safety facilities and equipment to be provided.

701.2 Responsibility. The owner of the premises shall provide and maintain such fire safety facilities and equipment in compliance with these requirements. A person shall not occupy as owner-occupant or permit another person to occupy any premises that do not comply with the requirements of this chapter.

[F] SECTION 702 MEANS OF EGRESS

702.1 General. A safe, continuous and unobstructed path of travel shall be provided from any point in a building or structure to the *public way*. Means of egress shall comply with the *International Fire Code*.

702.2 Aisles. The required width of aisles in accordance with the *International Fire Code* shall be unobstructed.

702.3 Locked doors. All means of egress doors shall be readily openable from the side from which egress is to be made without the need for keys, special knowledge or effort, except where the door bardware conforms to that permitted by the *International Building Code*.

702.4 Emergency escape openings. Required emergency escape openings shall be maintained in accordance with the code in effect at the time of construction, and the following. Required emergency escape and rescue openings shall be operational from the inside of the room without the use of keys or tools. Bars, grilles, grates or similar devices are permitted to be placed over emergency escape and rescue openings provided the minimum net clear opening size complies with the code that was in effect at the time of construction and such devices shall be releasable or removable from the inside without the use of a key, tool or force greater than that which is required for normal operation of the escape and rescue opening.

[F] SECTION 703 FIRE-RESISTANCE RATINGS

703.1 Fire-resistance-rated assemblies. The required fire-resistance rating of fire-resistance-rated walls, fire stops, shaft enclosures, partitions and floors shall be maintained.

703.2 Opening protectives. Required opening protectives shall be maintained in an operative condition. All fire and smokestop doors shall be maintained in operable condition. Fire doors and smoke barrier doors shall not be blocked or obstructed or otherwise made inoperable.

[F] SECTION 704 FIRE PROTECTION SYSTEMS

704.1 General. All systems, devices and equipment to detect a fire, actuate an alarm, or suppress or control a fire or any combination thereof shall be maintained in an operable condition at all times in accordance with the *International Fire Code*.

704.1.1 Automatic sprinkler systems. Inspection, testing and maintenance of automatic sprinkler systems shall be in accordance with NFPA 25.

704.2 Smoke alarms. Single- or multiple-station smoke alarms shall be installed and maintained in Groups R-2, R-3, R-4 and in dwellings not regulated in Group R occupancies, regardless of *occupant* load at all of the following locations:

- 1. On the ceiling or wall outside of each separate sleeping area in the immediate vicinity of *bedrooms*.
- 2. In each room used for sleeping purposes.
- 3. In each story within a dwelling unit, including basements and cellars but not including crawl spaces and uninhabitable attics. In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm justalled on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level

Single- or multiple-station smoke alarms shall be installed in other groups in accordance with the *International Fire Code*.

704.3 Power source. In Group R occupancies and in dwellings not regulated as Group R occupancies, single-station smoke alarms shall receive their primary power from the building wiring provided that such wiring is served from a commercial source and shall be equipped with a battery backup. Smoke alarms shall emit a signal when the batteries are low. Wiring shall be permanent and without a disconnecting switch other than as required for overcurrent protection.

Exception: Smoke alarms are permitted to be solely battery operated in buildings where no construction is taking place, buildings that are not served from a commercial power source and in existing areas of buildings undergoing alterations or repairs that do not result in the removal of interior wall or ceiling finishes exposing the structure, unless there is an attic, crawl space or basement available which could provide access for building wiring without the removal of interior finishes.

704.4 Interconnection. Where more than one smoke alarm is required to be installed within an individual dwelling unit in Group R-2, R-3, R-4 and in dwellings not regulated as Group R occupancies, the smoke alarms shall be interconnected in such a manner that the activation of one alarm will activate all of the alarms in the individual unit. The alarm shall be clearly audible

FIRE SAFETY REQUIREMENTS

in all bedrooms over background noise levels with all intervening doors closed.

Exceptions:

- 1. Interconnection is not required in buildings which are not undergoing alterations, repairs or construction of any kind.
- 2. Smoke alarms in existing areas are not required to be interconnected where alterations or repairs do not result in the removal of interior wall or ceiling finishes exposing the structure, unless there is an attic, crawl space or basement available which could provide access for interconnection without the removal of interior finishes.

CHAPTER 8

REFERENCED STANDARDS

This chapter lists the standards that are referenced in various sections of this document. The standards are listed herein by the promulgating agency of the standard, the standard identification, the effective date and title and the section or sections of this document that reference the standard. The application of the referenced standards shall be as specified in Section 102.7.

A	47	F2. /I		
\mathbf{A}		V	ΙН,	

American Society of Mechanical Engineers

Three Park Avenue New York, NY 10016-5990

<u>4</u>	100,100,111	
Standard		Referenced
reference		in code
nnmber	Title	section number
A17.I/CSA B44—2007	Safety Code for Elevators and Escalators	

ASTM

ICC

ASTM International 100 Barr Harbor Drive

West Conshohocken, PA 19428-2959

Standard reference		Referenced in code
number	Title	section number
F1346—91 (2003)	Performance Specifications for Safety-Covers and Labeling Requirements for All Covers for Swimming Pools, Spas and Hot Tubs	

International Code Council 500 New Jersey Avenue, NW

6th Floor

Washington, DC 20001

Standard reference number	Title	Referenced in code section number
IBC-09		
IFC-09		
IEBC—09	International Existing Building Code [©]	
TFGC—09	International Fuel Gas Code®	
IMC-09	International Mechanical Code®	
IPC-09	International Plumbing Code®	
IZC-09	International Zoning Code®	

NFPA

National Fire Protection Association

1 Batterymarch Park Quiney, MA 02269

Quiney, in a baboy	
	Referenced
	in code
Title	section number
Inspection, Testing and Maintenance of Water-based Fire Protection Systems	704.1.1
National Electrical Code	
	Title Inspection, Testing and Maintenance of Water-based Fire Protection Systems



APPENDIX A

BOARDING STANDARD

The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.

A101 GENERAL

A101.1 General. All windows and doors shall be hoarded in an *approved* manner to prevent entry by unauthorized persons and shall be painted to correspond to the color of the existing structure.

A102 MATERIALS

A102.1 Boarding sheet material. Boarding sheet material shall be minimum 1/2-inch (12.7 mm) thick wood structural panels complying with the *International Building Code*.

A102.2 Boarding framing material. Boarding framing material shall be minimum nominal 2-inch by 4-inch (51 mm by 102 mm) solid sawn lumber complying with the *International Building Code*.

A102.3 Boarding fasteners. Boarding fasteners shall be minimum ³/₈-inch (9.5 mm) diameter carriage holts of such a length as required to penetrate the assembly and as required to adequately attach the washers and nuts. Washers and nuts shall comply with the *International Building Code*.

A103 INSTALLATION


A103.1 Boarding installation. The boarding installation shall be in accordance with Figures A103.1(1) and A103.1(2) and Sections A103.2 through A103.5.

A103.2 Boarding sheet material. The boarding sheet material shall be cut to fit the door or window opening neatly or shall be cut to provide an equal overlap at the perimeter of the door or window.

A103.3 Windows. The window shall be opeued to allow the carriage holt to pass through or the window sash shall be removed and stored. The 2-inch by 4-inch (51 mm by 102 mm) strong back framing material shall be cut minimum 2 inches (51 mm) wider than the window opening and shall be placed on the inside of the window opening 6 inches minimum above the bottom and below the top of the window opening. The framing and boarding shall be predrilled. The assembly shall be aligned and the bolts, washers and nuts shall be installed and secured.

A103.4 Door walls. The door opening shall be framed with minimum 2-inch by 4-inch (51 mm by 102 mm) framing material secured at the entire perimeter and vertical members at not more than 24 inches (610 mm) on center. Blocking shall also be secured at not more than 48 inches (1219 mm) on center vertically. Boarding sheet material shall be secured with screws and nails alternating every 6 inches (152 mm) on center.

A103.5 Doors. Doors shall be secured by the same method as for windows or door openings. One door to the structure shall be available for authorized entry and shall be secured and locked in an approved manner.



INDEX

CARDO Berrary	1 AUG
A YOU PHICA	Research reports
ACCESS	APPROVED
Emergency egress702	Alternative materials, methods and
From bedrooms	equipment105.2
Plumbing fixtures, access for cleaning 504.2	Definition
To public way	Energy conservation devices
Toilet room as passageway 503.1	
Water closet	Fireplaces
ADJACENT	Garbage storage facilities
Privacy (hotel units, rooming units)	Modifications
	Used materials and equipment
ADMINISTRATION Scope101.2	ARCHITECTURAL
	Structural members
AGENT (See also OPERATOR, OWNER)	Trìm304.8
Definition	ARTIFICIAL
AIR	Lighting of habitable rooms 401.3
Combustion air603.5	Lighting of other spaces402.3
AISLES	AUTOMOBILE
Minimum width	Motor vehicles
ALTERATION	AWNING
Applicability of other codes102.3	Signs, marquees and awnings304.9
Condemnation	
Inspection	Tagor and an expension
Prosecution	В
Unlawful acts	BALCONY
ANCHOR	Handrails and guardrails 307.12
Anchored, definition	BASEMENT
Architectural trim	Definition
Signs, marquees and awnings304.9	Hatchways
APPEAL	
Application	Windows
Board decision	BATHROOM
Board of appeals	Common bathrooms 502.3, 503.1
Court review111.7	Hotels502,3
	Lighting
Disqualification	Locks
Financial interest	Outlets required
Hearing, emergency orders	Privacy
Membership	Ventilation
Notice of appeal	BATHTUB
Postponed hearing111.5	Required facilities502.1
Records	Rooming houses
Right to appeal	Sewage system
Vote	Water-heating facilities505.4
APPLIANCE	Water system
Cooking	
Mechanical	BOARDING Boarding standard Appendix A
APPLICABILITY	
General	BOILER
Referenced codes and standards 102.7	Unsafe equipment108.1.2
Application of references	
Other laws 102.10	
Other laws	CLASS PROFILE TO BE THE COMMENT
	CAPACITY
Alternatives	Heating facilities 602.2, 602.3, 602.4
Authority	CAR (Con AUTOMORIUE)
Modifications	CAR (See AUTOMOBILE)

great singletin will

CEILING	General108.1
Basement rooms	Notices and orders
Fire-resistance ratings	Placarding
Interior surfaces	Removal of placard
Minimum height	CONFLICT
CHANGE, MODIFY	Conflict of interest
Application of other codes	Violations
CHIMNEY	CONNECTION
Exterior structure	Sewage system
Elico 603 2 603 2	Water heating505.4
Flue	Water system
CLEANING	
Access for cleaning	001101110011011
Bathroom and kitchen floors	Existing structures
Disposal of garbage	CONTAINER
Disposal of rubbish	Garbage
Interior sanitation	Rubbish storage
Interior surfaces	CONTINUOUS
Plumbing facilities, maintained504.1	Unobstructed egress
Required plumbing facilities502	CONTRACTOR
Responsibility of persons305.1	Conflict of interest
Trash containers	
Vacant structures and land	CONTROL
CLEARANCE	Insect and rat control
Heating facilities	Safety controls
Plumbing fixtures	COOLING
CLOSING	Cooling towers
Streets	CORRIDOR
Vacant structures	Accumulation of rubbish
CLOTHES DRYER	Light
Exhaust	Lighting fixtures
	Ratings maintained
CODE OFFICIAL	Toilet rooms, access503.1
Condemnation	
Demolition	
Duties	D terreshood
Emergency order109	
Enforcement authority	DAMP, DAMPNESS Roofs
Failure to comply with demolition order	Window, door frames
Identification104.3	그리고 보고 하다는 것이 되어 하나면 한 경기를 들었다면 하지만 하는데 보고 있는데 그리고 하는데 하는데 하는데 하는데 하다 하나 하다.
Inspections	DANGEROUS, DAZARDOUS
Liability, relief of personal	Condemnation
Membership of board of appeals	Demolition
Notice of violation	Electrical hazards604.3
Notices and orders	Existing remedies102.4
Official records	Fire safety701
Personal liability	Imminent danger
Placarding	Unsafe equipment
Prosecution	Unsafe structures or premises
Removal of placard	DECKS
Right of entry	Handrails and guardrails
Transfer of ownership107.5	Maintenance
Vacant structures	DECORATION
Voting of appeals board	Exterior structure304 8
COMBUSTION	Exterior structure
Combustion air	Existing remedies102.4
COMPONENT SERVICEABILITY	Egiture to comply
Unsafe conditions	Failure to comply
CONDEMNATION	General
Closing of vacant structures	Order
Follure to comply	Salvage materials
Failure to comply	Violations

DETECTORS	Lighting fixtures
Smoke704	Receptacles
DETERIORATION	Responsibility
Definition	Service
Exterior walls	ELEVATOR, ESCALATORS, DUMBWAITERS
	Condemnation
DIRECT	
Egress702.1	General
DISPOSAL	Maintenance
Disposal of garbage	EMERGENCY
Disposal of rubbish	Emergency measures109
	Emergency orders
DOOR	Emergency escape openings 702.4
Exit doors	
Fire703.2	
Hardware	Duties and powers104
Insect screens	Scope101.2
Interior surfaces	EQUIPMENT
Locks304.15, 702.3	Alternative
Maintenance	Combustion air
Weather tight	Condemnation
Window and door frames	Electrical installation
	Emergency order
DORMITORY (ROOMING HOUSE, HOTEL, MOTEL)	Energy conservation devices
Locked doors	
Privacy	Installation
DRAIN, DRAINAGE	Interior structure
Basement hatchways304.16	Placarding
Plumbing connections506	Prohibited use108.5
Storm drainage	Responsibility601.2
	Safety controls
DUCT	Scope101.2
Exhaust duct304.9	Scope, mechanical and electrical 601.1
Duct systems	Support, definition202
DUST	Unsafe108
Process ventilation	Used
DWELLING	EAHAOOI
Cleanliness	Clothes dryer
Definition	Exhaust ducts
Electrical604.1	Process ventilation403.4
Heating facilities	EXISTING
Required facilities	Remedies102.4
PART OF MAN SELECT	Scope101.2
E 673900	Structural members
E Sept Sept Sept Sept Sept Sept Sept Sept	Structures101.3
EGRESS	
The state of the s	EXTERIOR
Aisles	Decorative features
Emergency escape	Exterior structure304
General	Exterior walls
Lighting	Painting
Locked doors	Rodent harborage
Obstructions prohibited	Sanitation304.1
Stairs, porches and railings	Scope301.1
305.4, 305.5, 307.1	Stair
ELECTRIC, ELECTRICAL EQUIPMENT	Street numbers
	Unsafe conditions
Abatement of hazards, fire exposure 604.3.2	
Abatement of hazards, water exposure 604.3.1	Weather tight303.13
Condemnation	1,200,000
Electrical equipment	
Facilities required	
Hazards	FAN
Installation	Exhaust vents302.6

FEES, EXPENSES, COST	HANDRAILS AND GUARDRAILS
Closing vacant structures108.2	Handrails
Demolition	Stairs and porches
Extermination 309.2, 309.3, 309.4, 309.5	HARDWARE
General	Door hardware
Relief from personal liability103.4	Openable windows
FENCE	HAZARDOUS (See DANGEROUS, HAZARDOUS)
Accessory	LIEAT LIEATING
Maintenance	Energy conservation devices
FIRE	Fireplaces
Automatic sprinkler systems	Heating603.1
Fire-protection systems703.1	Mechanical equipment603.1
Responsibility, fire safety	Required capabilities602
Scope101.2	Residential heating 602.2, 602.3
Scope, fire safety	Supply
Smoke alarms	Water heating facilities
FLAMMABLE LIQUID	Water system505
Containers	HEIGHT
ELOOP ELOOPING	Minimum ceiling height404.3
Area for steeping purposes	HOT (See HEAT, HEATING)
Fire-resistance ratings	HOTELS, ROOMING HOUSES AND DORMITORY
Interior surfaces	UNITS, MOTELS
Space requirements	Definition
FOOD PREPARATION	Locked doors
Cooking equipment	Required facilities
Sanitary condition	Toilet rooms503
Ventilation	HOUSEKEEPING UNIT
FOUNDATION	Definition
Condemnation108.1.1	230 vincing visit)
Foundation walls304.5	197
FRAME	Ethia i Implificacional/E
Window and door frames304.13	IDENTIFICATION
COR THE CONTRACTOR CON	IDENTIFICATION Code official
G	
GAS	INFESTATION
Energy conservation devices603.6	Condemnation
Exhaust vents	Insect and rat
GLAZING Materials	INSECTS Pest elimination
GRADE	Infestation
Drainage	Insect screens
GUARD	
Anchorage and maintenance304.12	INSPECTIONS
Basement windows	General
Definition	•
500000000000000000000000000000000000000	INSPECTOR
	Identification
Н	Inspections
HABITABLE	
Definition	INTENT
Light402	Code
Minimum ceiling height	INTERIOR
Minimum room width	Interior structure
Required plumbing facilities	Interior surfaces
Residential heating facilities 602.2, 602.3	Means of egress
Space requirements	Sanitation
ventuation	Onsale conditions

J	MATERIAL
JURISDICTION	Alternative
Title	Salvage
	Used
К	MEANS OF EGHESS (See EGHESS)
	MECHANICAL Installation
KITCHEN Floatrical authors required 605.0	Responsibility 601.2
Electrical outlets required	Scope
Prohibited use	Ventilation, general
Room lighting	Ventilation, toilet rooms
Water heating facilities505.4	MINIMUM
	Ceiling height
1.	Room width
I ANDING	Scope301.1
LANDING Handrails and guards	MODIFICATION
305.4, 305.5, 306.1	Approval
Maintenance	MOTEL (See HOTELS) MOTOR VEHICLES
LAUNDRY	
Room (ighting	Inoperative
Water-heating facilities505.4	Tanking 1
LAVATORY	50
Hotels502.3	N
Required facilities	NATURAL
Rooming houses	Lighting
Water-heating facilities505.4	Ventilation
Water system	NOTICES AND ORDERS
LEASE (SELL, RENT)	Appeal
Heat supplied	Method of service
Salvage materials110.4	Orders
Transfer of ownership	Owner, responsible person 107.1
LIEN	Penalties107.5
Closing of vacant structures	Placarding of structure
Demolition	Transfer of ownership
LIGHT, LIGHTING	Unauthorized tampering
Common halls and stairways	MANAGEMENT
General	Process ventilation
Habitable rooms402.1	Weeds
Luminaires	NUISANCE
Other spaces	Closing of vacant structures 108.2
Responsibility	
Toilet rooms	O CHARLES
LIVING BOOM	· ·
Room area	OBSTRUCTION Light
LOAD, LOADING	Right of entry
Elevators, escalators and dumbwaiters 606.1	OCCUPANCY (See USE)
Handrails and guardrails304.12, 305.5	OPENABLE
Live load	Locked doors
Stairs and porches	Windows
Structural members304.4, 305.2	OPERATOR
	Definition
M	ORDER (See NOTICE)
MAINTENANCE	ORDINANCE, RULE
Required	Applicability102

Application for appeal111.1	Responsibility
OUTLET	Sanitary drainage system
Electrical605.2	Scope501.1
OWNER	Storm drainage
Closing of vacant structures	Supply
Definition	Water heating facilities505.4
Demolition	PORCH
Pest elimination	Handrails
Failure to comply	Structurally sound304.10
Insect and rat control 302.5, 309.2, 309.4	PORTABLE (TEMPORARY)
Notice	Cooking equipment
Placarding of structure	PRESSURE
Responsibility301.2	Water supply505.3
Responsibility, fire safety	
Responsibility, light, ventilation 401.2	PRIVATE, PRIVACY
Responsibility, mechanical and electrical 601.2	Bathtub or shower
Responsibility, plumbing facilities 501.2	Occupancy limitations
Right of entry	Required plumbing facilities
Rubbish storage	Sewage system
Scope	Water closet and lavatory503.1
Transfer of ownership	Water system
The total of our loss in processing the control of	PROPERTY, PREMISES
	Cleanliness
P	Condemnation108
	Definition
PASSAGEWAY	Demolition
Common hall and stairway	Emergency measures109
Interior surfaces	Exterior areas
Toilet rooms, direct access503.1	Pest elimination, multiple occupancy 302.5, 309.4
PENALTY	Pest elimination, single occupancy 302.5, 309.3
Notices and orders107.4	Failure to comply
Placarding of structure108.4	Grading and drainage
Prohibited occupancy	Responsibility301.2
Removal of placard	Responsibility
Scope	Storm drainage
Violations	Vacant structures and land301.3
DECT EL BAINIATION	PROTECTION
PEST ELIMINATION Condemnation	Basement windows
Definition	Fire-protection systems
Insect and rat control 302.5, 304.5, 304.14, 309.1	Signs, marquees and awnings304.9
Pest elimination	PUBLIC
Responsibility of owner	Cleanliness
Responsibility of tenant-occupant 306.3, 306.5	Egress
	Hallway502.3
PLACARD, POST	
Closing	Sewage system
Condemnation	Vacant structures and land
Demolition	
Emergency, notice	Water system
Notice to owner	PUBLIC WAY
Placarding of structure	Definition
Prohibited use	
Removal	D
PLUMBING	R
Clean and sanitary504.1	RAIN (PREVENTION OF ENTRY INTO BUILDING
Clearance	EXTERIOR ENVELOPE)
Connections	Basement hatchways
Contamination	Exterior walls
Employee's facilities 503.3	Grading and drainage
Fixtures504.1	Roofs
Required facilities	Window and door frames
•	

RECORD	Minimum width404.2
Official records104.7	Overcrowding404.5
REHABILITATION	Prohibited use
Intent	Temperature
REPAIR	Toilet
Application of other codes	Ventilation
Chimneys304.11	ROOMING HOUSES (See DORMITORY)
Demolition	RUBBISH
Exterior surfaces	Accumulation
Maintenance	Definition
Signs, marquees and awnings304.9	Disposal
Stairs and porches	Garbage facilities
Weather tight	Rubbish storage
Workmanship	
REPORTS 10F 2.0	S
Test reports	
RESIDENTIAL	SAFETY, SAFE
Pest elimination	Fire safety requirements 701, 702, 703, 704
Residential heating	Safety controls
Scope	SANITARY
RESPONSIBILITY Pest elimination	Bathroom and kitchen floors
Fire safety701.2	Cleanliness
Garbage disposal	Disposal of garbage
General301.2	Disposal of rubbish
Mechanical and electrical601.2	Exterior property areas
Persons	Food preparation
Placarding of structure108.4	Furnished by occupant
Plumbing facilities501.2	Grease interceptors
Rubbish storage	Interior surfaces
Scope	Plumbing fixtures
REVOKE, REMOVE	Required plumbing facilities 502
Demolition110	Scope
Existing remedies	SASH
Removal of placard	Window
Rubbish removal	SCREENS
RIGHT OF ENTRY	Insect screens
Duties and powers of code official 104.3	SECURITY
Inspections	Basement hatchways304.18.3
RODENTS	Building
Basement hatchways	Doors
Exterior surfaces	Vacant structures and land301.3
Pest elimination	Windows
Guards for basement windows304.17	SELF-CLOSING SCREEN DOORS
Harborage	Insect screens
Insect and rodent control	SEPARATION
ROOF	Fire-resistance ratings703
Exterior structure	Privacy
Roofs	Separation of units
Storm drainage	Water closet and lavatory502.1
ROOM	SERVICE
Bedroom and living room404.4	Electrical
Cooking facilities	Method
Direct access	Service on occupant
Habitable	The state of the s
Heating facilities	SEWER General506.1
Light	Maintenance
minimum coming heights	Mantonalio

SHOWER	Scope301.1
Bathtub or shower502.1	Structural members
Rooming houses502.2	Vacant structures and land301.3
Water-heating facilities505.4	SUPPLY
Water system	Combustion air
SIGN	Connections
Signs, marquees and awnings304.9	Water-heating facilities505.4
Unauthorized tampering	Water supply
SINGLE-FAMILY DWELLING	Water system505
Extermination	SURFACE
SINK	Exterior surfaces
Kitchen sink	Interior surfaces
Sewage system	ŚWIMMING
Water supply505.3	Swimming pools
	Safety covers
SIZE	calcty sovoic
Habitable room, light	
Habitable room, ventilation	ROL VALOUEN SAN
Room area404.4.1	TEMPERATURE
SMOKE	Nonresidential structures 602.4
Alarms	Residential buildings 602.2
Interconnection704.4	Water-heating facilities505,4
Power source	TENANT
SPACE	Scope101.2
General, light	
General, ventilation	TEST, TESTING Agency105.3.2
Occupancy limitations	Agency
Privacy	Methods
Scope401.1	Reports
STACK	Required,.105.3
Chimneys	TOXIC Process ventilation403.4
STAIRS	TRACII
Common halls and stairways, light 402.2	Rubbish and garbage
Exit facilities	
Handrails304.12, 305.5	Approximate the second
Lighting	TANK U Emery result
Public areas	UNOBSTRUCTED
Stairs and porches	Access to public way702.1
STANDARD	General, egress
Referenced102.7	UNSAFE STRUCTURES AND EQUIPMENT
STOP WORK ORDER	Abatement methods108.6
Authority112.1	Dangerous structure or premises
Emergencies	Equipment
Failure to comply	Existing remedies102.4
Issuance112.2	General, condemnation
STORAGE	General, demolition110
	Notices and orders
Food preparation	Record
Rubbish storage facilities	Structures
Sanitation	USE
	Application of other codes
STRUCTURE 000 7	General, demolition
Accessory structures	
Closing of vacant structures	UTILITIES Authority to disconnect 109.2.1
Definition	Authority to disconnect
Emergency measures	
General condemnation 110	V
General, condemnation	VACANT
General, interior structure	VACANT Abatement methods108.6
riacatumy of structure	Anatement diethous

Authority to disconnect service utilities 108.2.1	WATER
Closing of vacant structures	Basement hatchways304.16
Emergency measure109	Connections
Method of service 107.3, 108.3	Contamination
Notice to owner or to	General, sewage506
person responsible 107, 108.3	General, storm drainage 507
Placarding of structure108.4	General, water system
Record	Heating
Vacant structures and land301.3	Hotels502.3
VAPOR	Kitchen sink
Exhaust vents	Required facilities
	Rooming houses
VEHICLES	Supply
Inoperative	System505
Painting302.8	Toilet rooms503
VENT	Water-heating facilities505.4
Connections	WEATHER, CLIMATE
Exhaust vents302.6	Heating facilities
Flue	
VENTILATION	WEATHERSTRIP
Clothes dryer exhaust	Window and door frames304.13
Combustion air	WEEDS
Definition	Noxious weeds
General, ventilation	WIDTH
Habitable rooms403.1	Minimum room width
Process ventilation403.4	WIND
Recirculation	Weather tight
Toilet rooms	Window and door frames304.13
VERMIN	WINDOW
Condemnation108	Emergency escape702.4
Insect and rat control	Glazing
VIOLATION	Guards for basement windows304.17
Condemnation	Habitable rooms402.1
General	Insect screens
Notice107, 108.3	Interior surface
Penalty	Light
Placarding of structure108.4	Openable windows
Prosecution	Toilet rooms
Strict liability offense	Ventilation
Transfer of ownership	Weather tight
•	Window and door frames304.13
e A F	WORKMANSHIP
W	General102.5
WALK	
Sidewalks302.3	
WALL	
Accessory structures	
Exterior surfaces	
Exterior walls	
Foundation walls	
General, fire-resistance rating 703.1	
Interior surfaces	
Outlets required	
Temperature measurement	
WASTE	
Disposal of garbage308.3	
Disposal of rubbish	
Dwelling units502.1	
Garbage storage facilities	

Don't Miss Out On Valuable ICC Membership Benefits. Join ICC Today!

Join the largest and most respected building code and safety organization. As an official member of the International Code Council®, these great ICC® benefits are at your fingertips.

EXCLUSIVE MEMBER DISCOUNTS

ICC members enjoy exclusive discounts on codes, technical publications, seminars, plan reviews, educational materials, videos, and other products and services.

TECHNICAL SUPPORT

ICC members get expert code support services, opinions, and technical assistance from experienced engineers and architects, backed by the world's leading repository of code publications.

FREE CODE-LATEST EDITION

Most new individual members receive a free code from the latest edition of the International Codes. New corporate and governmental members receive one set of major International Codes (Building, Residential, Fire, Fuel Gas, Mechanical, Plumbing, Private Sewage Disposal).

FREE CODE MONOGRAPHS

Code monographs and other materials on proposed International Code revisions are provided free to ICC members upon request.

PROFESSIONAL DEVELOPMENT

Receive Member Discounts for on-site training, institutes, symposiums, audio virtual seminars, and on-line training! ICC delivers educational programs that enable members to transition to the



I-Codes[®], interpret and enforce codes, perform plan reviews, design and build safe structures, and perform administrative functions more effectively and with greater efficiency. Members also enjoy special educational offerings that provide a forum to learn about and discuss current and emerging issues that affect the building industry.



ENHANCE YOUR CAREER

ICC keeps you current on the latest building codes, methods, and materials. Our conferences, job postings, and educational programs can also help you advance your career.

CODE NEWS

ICC members have the inside track for code news and industry updates via e-mails, newsletters, conferences, chapter meetings, networking, and the ICC website (www.iccsafe.org). Obtain code opinions, reports, adoption updates, and more. Without exception, ICC is your number one source for the very latest code and safety standards information.

MEMBER RECOGNITION

Improve your standing and prestige among your peers. ICC member cards, wall certificates, and logo decals identify your commitment to the community and to the safety of people worldwide.

ICC NETWORKING

Take advantage of exciting new opportunities to network with colleagues, future employers, potential business partners, industry experts, and more than SO,000 ICC members. ICC also has over 300 chapters across North America and around the globe to help you stay informed on local events, to consult with other professionals, and to enhance your reputation in the local community.

JOIN NOW! 1-888-422-7233, x33804 | www.iccsafe.org/membership



People Helping People Build a Safer World"



VALUABLE GUIDES TO THE 2009 I-CODES®



NEW!

SIGNIFICANT CHANGES TO THE 2009 INTERNATIONAL CODES®

Valuable resources for anyone using the International Codes! Each book offers a comprehensive yet practical analysis of the critical changes made between the 2006 and 2009 editions of the codes. Changes are identified then followed by in-depth discussion of how the change affects real-world application. Coverage reflects provisions with special significance, including new and innovative design ideas and technologies, modern materials and methods of construction, and current approaches to safety and stability. Authored by ICC code experts, these useful tools are "must-have" guides to the many important changes in the 2009 International Codes.

SIGNIFICANT CHANGES TO THE INTERNATIONAL BUILDING CODE, 2009 EDITION (365 pages)

Authors Doug Thornburg, AIA, and John Henry, P.E.

#7024509

SIGNIFICANT CHANGES TO THE INTERNATIONAL RESIDENTIAL CODE, 2009 EDITION (350 pages)

Author Stephen A. Van Note

#7101509

SIGNIFICANT CHANGES TO THE INTERNATIONAL FIRE CODE, 2009 EDITION (300 pages)

Author Scott Stookey

#7404509

SIGNIFICANT CHANGES TO THE INTERNATIONAL PLUMBING CODE/INTERNATIONAL MECHANICAL CODE/INTERNATIONAL FUEL GAS CODE, 2009 EDITION (220 pages)

Authors Bob Konyndyk, Scott Stookey, and Jay Woodward

#7202S09



Innovative Building Products

Make sure they are up to code with ICC-ES Evaluation Reports

The ICC-ES Solution

ICC Evaluation Service (ICC-ES*), a subsidiary of ICC*, was created to assist code officials and industry professionals in verifying that new and innovative building products meet code requirements. This is done through a comprehensive evaluation process that results in the publication of ICC-ES Evaluation Reports for those products that comply with requirements in the code or acceptance critera. Today, more code officials prefer using ICC-ES Evaluation Reports over any other resource to verify products comply with codes.



Mart Wilely Accepted and Frame

ICC-ES Evaluation Report

ESR-4802

Issued March 1, 2008

This report is subject to re-examination in one year.

www.icc-es.org | 1-800-423-6587 | (562) 699-0543

A Subsidiary of the international Code Council®

DIVISION: 07—THERMAL AND MOISTURE PROTECTION Section: 07410—Metal Roof and Wall Panels

REPORT HOLDER:

ACME CUSTOM-RILT PANELS 52380 FLOWER STREET CHCO, MONTANA 43820 (808) 884-1512 mbiltpanels.com

EVALUATION SUBJECT:

CUSTOM-BILT STANDING SEAM METAL ROOF PANELS: CB.

- 1.0 EVALUATION SCOPE
- Compliance with the following codes:
- 2006 International Building Code" (IBC)
- 2006 International Residential Code²⁰ (IRC)
- Weather resistance
- Wind uplift resistance

Custom-Bit Standing Scam Metal Roof Panels are stock panels complying with IBC Section 1507.4 and IRC Section 18905.10. The punels are recognized for use as Glass A roof coverings when installed in accordance with this report.

3.0 DESCRIPTION

3.1 Roofing Panels:

3.1 Roofing Panets: Custom-Bit standing seam roof panets are fobricated in wheel and are available in the CB-190 and St.-1750 profiles. The panels are off-formed at the ploate to provide the standing seams between parets. See Figures 1 and 3 for panels grofiles. The standing seam roof panets are roof-formed from multipum No. 24 gags (0.024 lost) thick (0.61 mms)) conf-ionmed sheet steel. The steel conforms to ASTM A 702, with an alternium-princ along configuration of AZ50.

Solid or closely fitted decking must be marinum "familiah thick (11.9 mm) wood stardard prace or lumber sheating complying with IBC Section 2304.7.2 or IRC Section 1999, in

INSTALLATION

4.1 General:

hastallation of the Custom-Bill Standing Seam Roof Patiels must be in accordance with this report. Section 1507.4 of the IBC or Section R905 to of the IRC, and the manufacturar's

published installation instructions. The manufacturer's risstallation instructions must be available at the jobelite at all times during installation. The roof panels must be installed as solid or tokeshy fitted decking, as specified in Secilian 3.2. Accessories such as guilters, forly angles, factors, ridgo caps, window or jabile tim, valley and hij flashings, etc., are fairnested to suit each job condition. Delaits must be submitted to be code official for each installation.

4.2 Roof Panel Installation:
4.2 Roof Panel Installation:
4.2.1 CB-150; The CD-150 roof panels are installed on roof shaving a minimum slope of 2:12 (17 percent). The roof panels are installed over the optional underlayment and socured to the shealthing with the panel clip. The clips are located at each panel in 50 les papes of 0 inches 1152 mm) from all ends and at a maximum of 4 feet (1.22 m) on center elong the length of the risk and fastened with a minimum of two No. 10 by 1-inch pan head corrosion-resistant acrews. The panel first are mechanically seamed twice, each pass at 90 degrees, resulting in a double-locking fold.

4.3 Fire Classification:

4.4 Wind Uplift Resistance;

The systems described in Section 3.0 and installed in accordance with Sections 4.1 and 4.2 have an allowable wind uplift resistance of 45 pounds per square foot (2.15 kPa).

CONDITIONS OF USE

The standing searn motel roof genela described in this report comply with, or are suitable afternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the

- 9.1 Installation must comply with this repert, the applicable code, and the manufacturer's published installation instituctions. If there is a conflict between this report and the manufacturer's published installation instructions, this report governs.
- 5.2 The reprint design and leads must be determined to each project. Wind up a passure on any roof size must not except 45 pouros an aguste foot (2.15 kPa).

EVIDENCE SUBMITTED

Data in accordance with the ICC-ES Acceptance Criteria for Matal Roof Coverings (AG165), dated October 2007.

7.0 IDENTIFICATION

Each standing seam metal roof panel is identified with a label bearing the product name, the material type and gage, the Acroe Costorn-Bill Panels name and address, and the availuation report number (ESR-4802).

FREE Access to ICC-ES Evaluation Reports!



William Gregory Building and Plumbing Inspector Town of Yorktown, **New York**

"We've been using ICC-ES Evaluation Reports as a basis of product approval since 2002. I would recommend them to any jurisdiction bullding department, particularly in light of the many new products that regularly move into the market. It's good to have a group like ICC-ES evaluating these products with a consistent and reliable methodology that we can trust."



Becky Baker, CBO Director/Building Official Jefferson County, Colorado

"The ICC-ES Evaluation Reports are designed

with the end user in mind to help determine if building products comply with code. The reports are easily accessible, and the information is in a format that is useable by plans examiners and inspectors as well as design professionals and contractors."

VIEW ICC-ES EVALUATION REPORTS ONLINE!

www.icc-es.org

KC & Industry Representation to continue an expressible methodo or an other artificion in apectually subhered to consider prior continued at the object of the express procedure of the object of the object of the express procedure of the object of the obj



2009 INTERNATIONAL CODES ON I-QUEST

ICC offers an electronic option just right for you

This powerful tool contains the complete searchable text of the 2009 International Codes®.

I-Quest's Microsoft Fast Folio® search engine allows you to:

- · Enjoy multiple search capabilities
- Utilize hyperlinks to sections and tables within each code
- Copy and paste text, figures, and tables
- Highlight and bookmark frequently used sections
- · Add your own searchable notes to text or hide them
- · Use the "Update" feature to keep your code current
- · Available versions include:
 - The Complete Collection containing all 13 I-Codes plus ICC/ANSI A117.1-2003
 - IBC, IRC, or IFC individually

Please note, I-Quest is not MAC-compatible.



I-QUEST, SINGLE USER

Enables one code user to load CD content on one computer.

2009 COMPLETE COLLECTION

SINGLE | #8005Q09

2009 IBC°

SINGLE | #8000Q09

2009 IRC®

SINGLE | #8100Q09

2009 IFC°

SINGLE | #8400Q09

All versions include new Update feature!

I-QUEST, NETWORK

An ideal selection for code users working on a shared network. I-Quest Network allows a set number of concurrent users to access content.

2009 COMPLETE COLLECTION

FIVE USER | #8005Q509

2009 IBC°

FIVE USER | #8000Q509

2009 IRC°

FIVE USER | #8100Q509

2009 IFC°

FIVE USER | #8400Q509

10, 25, and 50 user versions are also available.

Call 1-888-422-7233, x33822 for details.

NEW!

I-QUEST, VOLUME LICENSING

For organizations with staff on the go, ICC offers the ideal solution. Purchasing a volume license enables your firm, office or jurisdiction to download CD content to a set number of computers. Whether the seats are fixed desktops in the office, laptops travelling the globe, or tablet PCs in the field, ICC's new Volume Licensing has you covered.

2009 COMPLETE COLLECTION

FIVE SEAT | #8005QL509

2009 IBC°

FIVE SEAT | #8000QL509

2009 IRC®

FIVE SEAT | #8100QL509

2009 IFC°

FIVE SEAT | #8400QL509

10, 25, and 50 seat versions are also available.

Call 1-888-422-7233, x33822 for details.

ORDER YOURS TODAY!
1-800-786-4452 | www.iccsafe.org/store